



Product Service

CERTIFICATE

No. Z2 099333 0057 Rev. 05

Holder of Certificate: **LONGi Green Energy Technology Co., Ltd.**
No. 388, Middle Hangtian Road
Chang'an District
710100 Xi'an City, Shaanxi
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-crystalline Silicon Photovoltaic module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704061601004-11

Valid until: 2024-11-10

Date, 2019-11-11

(David Bo)



Product Service

CERTIFICATE

No. Z2 099333 0057 Rev. 05

Model(s):

LR6-72HV-xxxM, (xxx=320-350 in step of 5)
LR6-60HV-xxxM, (xxx=270-300 in step of 5)
LR6-72PH-xxxM, (xxx=340-385 in step of 5)
LR6-60PH-xxxM, (xxx=280-320 in step of 5)
LR6-72MPH-xxxM, (xxx=340-380 in step of 5)
LR6-60MPH-xxxM, (xxx=280-320 in step of 5)
LR6-72OPH-xxxM, (xxx=370-420 in step of 5)
LR6-60OPH-xxxM, (xxx=310-365 in step of 5)
LR6-72HPH-xxxM, (xxx=350-405 in step of 5)
LR6-72HIH-xxxM, (xxx=350-405 in step of 5)
LR6-60HPH-xxxM, (xxx=295-335 in step of 5)
LR6-60HIH-xxxM, (xxx=295-335 in step of 5)
LR6-72HH-xxxM, (xxx=315-385 in step of 5)
LR6-60HH-xxxM, (xxx=265-320 in step of 5)
LR6-72HPH-xxxMC, (xxx=350-405 in step of 5)
LR6-60HPH-xxxMC, (xxx=295-335 in step of 5)
LR4-72HPH-xxxM, (xxx=400-460 in step of 5)
LR4-72HIH-xxxM, (xxx=400-460 in step of 5)
LR4-60HPH-xxxM, (xxx=330-380 in step of 5)
LR4-60HIH-xxxM, (xxx=330-380 in step of 5)
LR6-60ZPH-xxxM, (xxx=330-355 in step of 5)
LR4-72ZPH-xxxM, (xxx=420-435 in step of 5)
LR4-60ZPH-xxxM, (xxx=350-365 in step of 5)
xxx is standing for rated output power at STC

Parameters:

Fire Safety Class:	Class C
Application Class:	Class A
Max. System Voltage:	1500V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute. No.10 West Kaifa Road, Yangzhou 225009 Jiangsu, P.R.China.
Construction:	Framed, with Junction box, cable and connector.

Tested according to:

IEC 61215:2005
IEC 61730-1:2004
IEC 61730-1:2004/AMD1:2011
IEC 61730-1:2004/AMD2:2013
IEC 61730-2:2004
IEC 61730-2:2004/AMD1:2011
EN 61730-1:2007/A11:2014
EN 61730-2:2007/A1:2012

Production Facility(ies):

001192, 002875, 090968, 096558, 099605, 099606,
099626, 097323, 102892, 103410, 103841