

## Manufacturer Declaration

To whom it may concern

Regarding GSD8-I meters for UAB "VILNIAUS VANDENYS" tender

Hereby we confirm that the meters, to be supplied to UAB "VILNIAUS VANDENYS" tender, do comply with the technical requirements corresponding points:

The working medium of the meters is drinking water with possibility of chlorine compounds.

The working environment of the meters is air/water. The meters are corrosion resistant.

The metrological class ( $Q_3/Q_1$ ) is R100.

The height of the meters is not more than 90mm.

The meters are without the return valves. The return flow is measured in case there is such.

The meters can be mounted horizontally or vertically.

The protection class is not lower than IP65.

The connection type of the meters is threaded.

The calculation mechanism can be rotated in 360° angle.

The warranty period is 24 months.

Best regards,

