


Concise form of the test report No.: 1/28.04.23./PhM-14

Information about laboratory

Name of testing laboratory	BALTIC RESEARCH CENTER Ltd.
Date of issue of test report	28.04.2023.
Laboratory contact name	Ingmārs Felcis
Signature, Head of Laboratory Ingmārs Felcis	

Note: By signing this form, the signatory is attesting that the information on the form is correct and the same as on the original, complete test report(s). The signatory also attests that all of the results on this form measured entirely in accordance with IES LM-79-19, EN 13032:1 and EN 13032:4 standards.

Product information

Manufacturer	SIA "VIZULO"
Model number	SRLE 041 740 L17 AB032

Electrical measurements

Goniophotometer output

Power	41	W
Current	0.19	A
Voltage (AC)	230	V
Power factor	0.94	

Photometric characteristics

Total flux	6603	lm
Efficacy	161	lm/W
Correlated colour temperature CCT	4025	K
Colour rendering index CRI	72	

Environment

Ambient temperature of measure	25.0	°C
--------------------------------	------	----

