



Product Service

# CERTIFICATE

No. Z2 122610 0001 Rev. 00

**Holder of Certificate:** **Shinson Technology Co.,Ltd**  
Block#201, No.9 Chuangye Road  
213000 Changzhou, Jiangsu  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**




**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 701262322401-00

**Valid until:** 2028-07-13

**Date,** 2023-09-06





# CERTIFICATE

No. Z2 122610 0001 Rev. 00

## Model(s):

SxxxM72P3BF (xxx=525-560 in step of 5W)  
 SxxxM50P4BF (xxx=480-510 in step of 5W)  
 SxxxM66P4BF (xxx=635-675 in step of 5W)  
 SxxxM60P4BF (xxx=580-615 in step of 5W)  
 SxxxM60P3BF (xxx=465-480 in step of 5W)  
 SxxxM72P3 (xxx=530-550 in step of 5W)  
 SxxxM54P3 (xxx=400-410 in step of 5W)  
 SxxxM10C (xxx=355-365 in step of 5W)  
 SxxxM60P2B (xxx=360-380 in step of 5W)  
 SxxxM66P4BF (xxx=675-700 in step of 5W)  
 SxxxM60P4BF (xxx=615-635 in step of 5W)  
 SxxxT54P3BF (xxx=415-445 in step of 5W)  
 SxxxT66P4BF (xxx=675-715 in step of 5W)  
 SxxxN60BPV (xxx=460-480 in step of 5W)

### Black series:

SxxxN48BPV (xxx=355-365 in step of 5W)  
 SxxxM54P3BF (xxx=395-415 in step of 5W)  
 SxxxM54NF3BFB (xxx=415-445 in step of 5W)  
 SxxxM66NT4BF (xxx=675-715 in step of 5W)  
 SxxxM60NT3B (xxx=460-480 in step of 5W)  
 SxxxM54P3BFB (xxx=415-435 in step of 5W)  
 xxx is standing for rated output power at STC

## Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC
Construction:	Framed, double glass, with Junction box, cable and connector.
Fire Safety Class:	Class C according to UL790

## Tested according to:

IEC 61215-1:2021  
 IEC 61215-1-1:2021  
 IEC 61215-2:2021  
 IEC 61730-1:2016  
 IEC 61730-2:2016