



CONFORMITY CERTIFICATE AND INTERNAL TEST REPORT (UNI EN 10204 Tipo 3.1)

FORM
M102-P-04-8.2
Rev.: 3 del 28/08/2015

CUSTOMER:

DATE 14/10/2021 N° CERT. 40 2021

YOUR ORDER: dated 25/08/2021
OUR D.D.T.: 1905 dated 30/09/2021 ns. rif. CERX-N330982

WE CERTIFY THAT SEALING GASKETS IN:

POLYVALENT ELASTOMER EPDM

AND COATING IN:

THERMOPLASTIC ANTICORROSION COATING "RILSAN " NYLON 11

- A) ARE SUITABLE FOR POTABLE WATER ACCORDING TO THE NORMS APPROVED BY THE ITALIAN LAW:
- 2) HEALTH MINISTRY MEMORANDUM n. 102 DEL 02/12/78 - (all. III sez. 1)
- 3) D.L. 174 DATED 06/04/2004 "REGULATION ON MATERIALS AND OBJECTS THAT MAY BE USED IN STATIONARY COLLECTION, PRECESSING AND DISTRIBUTION OF WATER DESTINED FOR HUMAN CONSUMPTION"

AND TSE

FOLLOWING INTERNAL TESTS HAVE BEEN MADE ON PRODUCTS

- 1) VISUAL AND DIMENSIONAL QUALITY CONTROL AT 100%
- 2) PRESSURE TEST OF EVERY PRODUCT CATEGORY ACCORDING TO THE INTERNAL PROCEDURE P-04-8.2 (PROTOTYPE)

FOR WATER:

NOMINAL PRESSURE	10 bar	(1,0 Mpa)
TEST PRESSURE	15 bar	(1,5 Mpa)
WORKING PRESSURE	10 bar	(1,0 Mpa)



NOTE	NS. MOD.	Q.TY	DESTINATION
------	----------	------	-------------

We certify that the material listed above is strictly conform to the order requirements and above stated norms

NOVA SIRIA S.R.L.
Quality Assurance
Daniele Canavesio
TEL. 0121/342256

P.IVA E.C.F. 03716570017

Daniele Canavesio