

INDUSTEK UAB

DARIAUS IR GIRENO STR.177 - 02189 -
VILNIUS

LITUANIA

ROLETTO (TO), 27TH OCT 2021

SUBJECT: NOVA SIRIA DECLARATION

We hereby certify that:

POLYVALENT ELASTOMER EPDM AND THERMOPLASTIC ANTICORROSION COATING RILSAN NYLON 11 are used by Nova Siria in its production.

We are at your disposal to support you with documents and certificates what confirm this statement.

Kind regards,


Nova Siria
SINCE 1932
MARCO FERRERO
MANAGING DIRECTOR

Nova Siria S.r.l.
PLANT, HEADQUARTERS AND OFFICES

Via Marconi 4/6 - 10060 Roletto (TO) – ITALY
Tel. +39 0121 342256
Email: info@novasiria.it – novasiria@cert.dag.it
VAT Code / Partita IVA: 03716570019

Società soggetta all'attività di direzione e coordinamento di Hawle Beteiligungsgesellschaft mBH
Company subject to management and coordinatio by Hawle Beteiligungsgesellschaft mBH

INTERNATIONAL SALES OFFICE

Tel. +39 0121 342256
Email: export@novasiria.it
Codice Univoco Fatturazione Elettronica:
5RUO82D



www.novasiria.it



Certificate of Conformity

Product Range:	Nova Siria GRZ-EPDM-60x32 GOLA Nova Siria GRZ-EPDM-63x32-TRONCO CONICA
VIP Material Reference:	CVE78 EPDM 80+/-5 SHORE A HARDNESS
Physical Testing:	BS EN 681-1:1996 ; Elastomeric seals. Material requirements for pipe joint seals used in water and drainage applications. Vulcanized rubber
Potable Water:	WRAS (UK) Approval No: 1612514; Expiry: December 2021 BS 6920-2.1:2014 : Suitability of non-metallic materials and products for use in contact with water intended for human consumption with regard to their effect on the quality of the water. Attestation De Conformite Sanitaire (France); Expiry August 2020

This is to certify that the products referenced above manufactured by VIP-Polymers Ltd have been tested in accordance with the physical and microbiological standards described above.



VIP-Polymers Ltd
15 Windover Road,
Huntingdon,
Cambridgeshire PE29 7EB
Steve Casey B.Sc (Hons) C.Eng, Sales & Technical Director

Authorised Signatory:

February 2017

VIP-Polymers Ltd
15 Windover Road
Huntingdon
Cambridgeshire PE29 7EB

Tel: +44 (0)1480 411333
Fax: +44 (0) 1480 413991
sales@vip-polymers.com
www.vip-polymers.com

Approval Number: 1910523
Test Report: MA6755/Y 1-4 & MA6839/E



Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

2nd December 2019

Arkema
Cerdato-SRD L,
27470 Serquigny,
France

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

COATINGS, PAINTS & LININGS - FACTORY APPLIED PIPE & FITTINGS COATINGS.

5030

'Rilsan' polyamide powder coatings to be used in conjunction with 'Primgreen LAT 12035' epoxy resin primer.

The following grades are for use with water up to 60°C: T Blue 7443 MAC, T Green 7529 MAC, T Grey 5161 MAC and T White 1488 AC.

The following grade is for use with water up to 23°C: T Black 7450 AC.

Apply accordance with user instructions 'Dircom - 4418E/05.2015/20'. The coatings are approved when the piece to be coated is pre-heated to 330°C for 7 minutes – if the pre-heat is varied from this then the materials are not covered by the scope of the approval.

APPROVAL NUMBER: 1910523

APPROVAL HOLDER: ARKEMA

The Scheme reserves the right to review approval.

Approval 1910523 is valid between October 2019 and October 2024

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme

WRAS MATERIAL APPROVAL - MATERIALS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY

The material referred to in this letter is suitable for contact with water for domestic purposes. **Approval of this material does not signify the approval of its mechanical or physical properties for any use.**

Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that; 'the material as listed, having passed the tests of effect on water quality, is suitable for use in contact with wholesome water'

This may be abbreviated to 'Water Regulations Advisory Scheme - Approved Material' or 'WRAS Approved Material'.

The scope of an Approval does not extend to rebranded materials unless otherwise agreed by the Scheme.

Use of the WRAS Approved Material Logo

Approval holders may use the WRAS Approved Material logo and make reference to any approval issued by WRAS Ltd. in respect of a particular material or range of materials provided the approval is, and remains valid.

Approval holders are entitled to use the logo on the packing, promotional literature and point of sale advertising Approved Materials.

Modifications to existing Approvals

It is a condition of WRAS Material Approval that NO changes or modifications to the Approved Material, be made without the Approval Holder first notifying WRAS Ltd. Full details of the proposed changes must be provided to the Scheme. Failure to comply with this condition will immediately invalidate a previously granted Approval.

Re-Approval

WRAS will write to you 1 year before the approval expires asking whether you would like to renew it. Please complete the relevant section of the MA3 application form which will be included with the letter and return to WRAS (via e-mail or post).

Please note it is the responsibility of the Approval Holder to ensure the Approval remains valid. WRAS Ltd. accepts no liability for the delay in granting approval where this is caused by circumstances outside of the Scheme's control.