

7 Marking

Valves in accordance with this standard shall be marked in a durable and clearly visible manner in accordance with prEN 19: 1999 as follows:

- DN;
- identification of the shell material(s);
- PN;
- identification of the manufacturer;
- identification of the year of manufacture;
- number of the relevant part of this standard e.g. EN 1074-2.

For valves smaller than DN 50, only the three following marks shall be compulsory:

- PN;
- identification of the manufacturer;
- number of the relevant part of this standard e.g. EN 1074-2.

8 Packaging

Valves shall be packaged and/or protected by the manufacturer against mechanical damage and ingress of foreign matter during handling, transport and storage, in accordance with the manufacturer's instructions, except when otherwise agreed between manufacturer and purchaser.