

- The illumination measured facing the endline cameras will be an average maintained lux level of 1,000.
- The horizontal illumination immediately outside the further boundary line (team benches and courtside seats), measured 1m above the floor, will be an average maintained lux level of 2,000 lux.

Seating Area:

The horizontal illumination will gradually decrease following these guidelines:

- Row 1 to 7 will be an average maintained lux level of 1,250 (50% compared to the playing court).
- Row 8 to 14 will be an average maintained lux level of 625 (25% compared to the playing court).
- Row 15 to 21 will be an average maintained lux level of 375 (15% compared to the playing court).
- Row 22 and beyond will be an average maintained lux level of 125 (5% compared to the playing court).

General:

- Full arena lighting must be provided beginning 90 minutes prior to each game and must be maintained until 30 minutes following the end of the game.
- During team practices the illumination will be the same as during games.