

**We, Südkabel GmbH, having our premises at Rhenaniastrasse 12-30, 68199 Mannheim, Germany confirm that outdoor terminations filled with liquid insulation type EHFVC 123 meet these technical parameters:**

### **EHFVC 123**

- Post insulators material shall be: Epoxy resin;
- Electric field distribution method shall be: Geometrical;
- The grounding connection and coupling contacts shall be: Without soldering;
- Cable conductor connector shall be: Bolted.

