

TEST REPORT Nº 2416/0524/E1

NOT CUANTITAVE GENERAL CONCLUSION IS REFERRED TO THE ACCREDITED TESTING. Page 1 of 1

The present test report modifies and replaces the Report 2416/0524 issued by SGS on 2016 October 10th in order to include a new derived model.

Test site..... : EMC Laboratory of SGS Tecnos, Madrid, Spain
Test date..... : 2016 / 07 / 13 to 2016 / 07 / 22
Client : MEDICAL IBERICA, S.A.
Address : C/ LANZAHITA, 6 POL. IND. ALBARREJA
 28946 FUENLABRADA - MADRID (SPAIN)

Equipment tested..... : ARTICULATED HOSPITAL BED
State and reception date : CORRECT, 2016 / 06 / 23
Supplier : MEDICAL IBERICA, S.A.
Trade-mark..... : MEDISA
Model tested..... : GALAXY 2
Derived model not tested..... : MAJESTIC 2 (See page 6 of TRF 2416/0524/E1)
Serial Number : PROTOTYPE
Nominal Ratings : 230-110 V~; 50-60 Hz
Life-supporting equipment : No
Essential performance : No

Standards applied..... : *UNE-EN 60601-1-2:2008+Corr.:10*

Emission:

- *UNE-EN 55011:2011+A1:2011*
 - Conducted emission
 - Radiated emission (*)
- *UNE-EN 61000-3-2:2014(Harmonics)*
- *UNE-EN 61000-3-3:2013 (Voltage fluctuations)*

Immunity:

- UNE-EN 61000-4-2:2010; UNE-EN 61000-4-3:2007+A1:2008+A2:2011 (1)*
- UNE-EN 61000-4-4:2013; UNE-EN 61000-4-5:2015*
- UNE-EN 61000-4-6:2014; UNE-EN 61000-4-8:2011*
- UNE-EN 61000-4-11:2005*

(*) Radiated emission test, out of accreditation scope: ENAC Nº 5/LE011
 (1) Accredited up to 1 GHz

Results : Results obtained refer to the sample tested which is the subject of this Report, considering worst case values from tests and verifications carried out.
 Measurement uncertainties associated with variables determined during tests are available from the Laboratory at Customer's request.

Conclusion..... : According to the results obtained, the sample tested **COMPLIES** in the test condition performed with the prescriptions indicated in the specifications applied.

Madrid, 20 January 2017

| Tested by Project Engineer EMC | Verified by EMC Reviewer | Approval by Technical Manager of Test Laboratory |
|---|---|---|
|  |  |  |
| JOSÉ ALBERTO ORTEGA PAGE | JAVIER MORGADO DURÁN | FERNANDO MONTES CLAVER |

The present test report, with 1 page, and Annex TRF 2416/0524/E1, can not be copy partially without the written consent of SGS

Test Report issued under the responsibility of:




SGS Tecnos, S.A.


| | |
|--|---|
| TEST REPORT IEC 60601-1-2 Medical Electrical Equipment PART 1-2: General Requirements for Basic Safety and Essential Performance Collateral Standard: Electromagnetic Compatibility Laboratory Accredited by ENAC, with Accreditation N° 5/LE011, to perform the tests included in this Report. | |
| Report Reference No.: | 2416/0524/E1 |
| Date of issue | 2017/01/20 |
| Total number of pages..... | 57 |
| CE Testing Laboratory | SGS Tecnos, S.A. (Electric Test Laboratory) |
| Address | C/ Trespaderne, 29 – Edificio Barajas 1 28042 – MADRID (Spain) |
| Applicant's name..... | MEDICAL IBERICA, S.A. |
| Address | C/ LANZAHITA, 6 POL. IND. ALBARREJA 28946 FUENLABRADA - MADRID (SPAIN) |
| Test specification | Emission and immunity tests according to the following Standard |
| Standard | IEC 60601-1-2:2007 (Third Edition) |
| Test procedure | CE Examination |
| Non-standard test method..... | N/A |
| Test Report Form No..... | IEC60601_1_2CEMC |
| Test Report Form(s) Originator | UL |
| Master TRF..... | Dated 2013-04 |
| Copyright © 2013 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved. <small>This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context. If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed. This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.</small> | |
| Test item description | ARTICULATED HOSPITAL BED |
| Trade Mark | MEDISA |
| Manufacturer..... | MEDICAL IBERICA, S.A. |
| Model | GALAXY 2 |
| Derived model no tested | MAJESTIC 2 (See page 6) |
| Serial number | PROTOTYPE |
| Ratings | Input: 230 – 110 V~ / 50-60 Hz |

1.0 Testing Program Details

| | |
|--|---|
| Testing procedure and testing location: | |
| <input checked="" type="checkbox"/> CE Testing Laboratory: | SGS Tecnos, S.A. (Electric Test Laboratory) |
| Testing location/ address | C/ Trespaderne, 29 – Edificio Barajas 1 28042 – MADRID (Spain) |
| <input type="checkbox"/> Associated CB Test Laboratory: | |
| Testing location/ address | |
| Tested by (name + signature) | José Alberto Ortega Page  |
| Approved by (name + signature) : | Javier Morgado Durán  |
| <input type="checkbox"/> Testing procedure: TMP | |
| <input type="checkbox"/> Testing procedure: WMT | |
| <input type="checkbox"/> Testing procedure: SMT | |



| | |
|---|---|
| <p>List of Attachments (including a total number of pages in each attachment):</p> | |
| <p>Summary of testing:</p> | |
| <p>Tests performed (name of test and test clause): The equipment has been tested according to the following standards: UNE-EN 60601-1-2:2008 + Corr.:2010, official edition in Spanish language of European Standard EN 60601-1-2:2007 + Corr.:2007 technically equivalent to International Standard IEC 60601-1-2:2007</p> <p>Emission: -UNE-EN 55011:2011+A1:2011 - Conducted emission - Radiated emission (*) -UNE-EN 61000-3-2:2014(Harmonics) - UNE-EN 61000-3-3:2013 (Voltage fluctuations)</p> <p>Immunity: - UNE-EN 61000-4-2:2010 - UNE-EN 61000-4-3:2007+A1:2008 +A2:2011 - UNE-EN 61000-4-4:2013 - UNE-EN 61000-4-5:2015 - UNE-EN 61000-4-6:2014 - UNE-EN 61000-4-8:2011 - UNE-EN 61000-4-11:2005 (*) Test of Radiated Emission outside of accreditation scope ENAC Nº 5/LE011.</p> <p>All applicable tests according to the above specified standards have been carried out</p> <p>From the result of inspection and tests on the submitted sample, we conclude that it complies with the requirements of the Standards.</p> | <p>Testing location: SGS Tecnos, S.A. (Electric Test Laboratory) C/ Trespaderne, 29 - Edificio Barajas 1 28042 – MADRID (Spain)</p> |
| <p>Summary of compliance with National Differences</p> <p>List of countries addressed: EU Group differences (No specific EU countries tested)</p> <p><input checked="" type="checkbox"/> The product fulfils the requirements of IEC 60601-1-2:2007</p> | |



| |
|--|
| Test item description : ARTICULATED HOSPITAL BED Trade Mark : MEDISA Manufacturer : MEDICAL IBERICA, S.A. Model : GALAXY 2 Ratings : Input: 230 – 110 V~ / 50-60 Hz |
| Possible test case verdicts: - test case does not apply to test object...: N/A - test object does meet requirement: P (Pass) - test object does not meet requirement...: F (Fail) |
| Testing : Date of receipt of test item : 2016/06/23 Date(s) of performance of tests : 2016/07/13 to 2016/07/22 |
| General remarks: <p>The test results presented in this report relate only to the object tested.</p> <p>The results contained in this report reflect the results for this particular model and serial number. It is the responsibility of the manufacturer to ensure that all production models meet the intent of the requirements detailed within this report.</p> <p>This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at www.sgs.com/terms_and_conditions.htm and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.</p> <p>The present test report modifies and replaces the Report 2416/0524 issued by SGS on 2016 October 10th in order to include a new derived model (See page 6).</p> <p>This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.</p> <p>“(see Enclosure #)” refers to additional information appended to the report. “(see appended table)” refers to a table appended to the report.</p> <p>Results obtained refer to the samples tested which are the subject of this Report, considering worst case values from tests and verifications carried out.</p> |
| Throughout this report <input type="checkbox"/> point <input checked="" type="checkbox"/> comma is used as decimal separator. |
| General product information: Appliance is an articulated bed designed for adult patients admitted on hospitalization standard units as well as long-stay units. The EUT can perform the next movements through actuators and motors: <ul style="list-style-type: none"> - Lifting bed - Backrest section lifting - Upper legs section lifting - Trendelemburg and antitrendelembur positions |

| Report Index: | | |
|---------------|---|----|
| Item | Description | |
| 1.0 | Testing Program Details | 6 |
| 1.1 | Equipment Description | 6 |
| 1.1.1 | Equipment Marking Plate | 6 |
| 1.1.2 | Equipment Used During Test | 7 |
| 1.1.3 | Input/Output Ports | 7 |
| 1.1.4 | EUT Internal Operating Frequencies | 7 |
| 1.1.5 | Power Interface | 7 |
| 1.2 | EUT Operation Modes | 8 |
| 1.3 | EUT Configuration Modes | 8 |
| 1.4 | Immunity Performance Criteria | 8 |
| 1.5 | Compliance Summary | 9 |
| 1.6 | Result Summary | 12 |
| 1.7 | Test Conditions and Results – Conducted Emissions | 13 |
| 1.8 | Test Conditions and Results – Radiated Emissions | 22 |
| 1.9 | Test Conditions and Results – Disturbance Power Emissions | 21 |
| 1.10 | Test Conditions And Results – Limits for Harmonics Current Emissions | 22 |
| 1.11 | Test Conditions And Results – Limits for Voltage Fluctuations and Flicker | 35 |
| 1.12 | Test Conditions and Results – Immunity to electrostatic discharges | 39 |
| 1.13 | Test Conditions and Results – Immunity to RF electromagnetic fields | 43 |
| 1.14 | Test Conditions and Results – Electrical Fast Transients Immunity | 46 |
| 1.15 | Test Conditions and Results – Surge Immunity | 48 |
| 1.16 | Test Conditions and Results – Conducted Disturbances Immunity | 51 |
| 1.17 | Test Conditions and Results – Voltage Dips, Interruptions Immunity | 53 |
| 1.18 | Test Conditions and Results – Power Frequency Magnetic Immunity | 56 |

1.1 Equipment Description

General product information:

Appliance is an articulated bed designed for adult patients admitted on hospitalization standard units as well as long-stay units.

The EUT can perform the next movements through actuators and motors:

- Lifting bed
- Backrest section lifting
- Upper legs section lifting
- Trendelemburg and antitrendelembur positions



The difference between model tested (GALAXY 2) and derived model not tested (MAJESTIC 2) is the lift motors, due to the Galaxy 2 (DEWERT / MEGAMAT MCZ - 66208) raises with the compasses and the Majestic 2 (DEWERT / GAMMA COLONNE) raises with columns.

1.1.1 Equipment Marking Plate

Copy of marking plate (draft)



1.1.2 Supporting Equipment Used During Test:

| Use | Product Type | Manufacturer | Model | Comments |
|----------------------------|-------------------|-----------------|----------|----------|
| EUT | Medical equipment | MEDICAL IBERICA | GALAXY 2 | None |
| EUT – Equipment Under Test | | | | |

1.1.3 Input/Output Ports:

| Port No. | Name | Type* | Cable Max. >3m | Cable Shielded | Comments |
|---|-----------------|-------|----------------|----------------|----------|
| 0 | Enclosure | N/E | — | — | None |
| 1 | Mains | AC | -- | No | None |
| 2 | Movement handle | I/O | Yes >3m | -- | None |
| *Note: AC = AC Power Port N/E = Non-Electrical I/O = Input/Output signal port | | | | | |

1.1.4 EUT Internal Operating Frequencies:

| Frequency (MHz) | Description |
|----------------------------|-------------|
| Not specified by applicant | |

1.1.5 Power Interface

| Mode No. | Voltage (V) | Current (A) | Power (W) | Frequency (DC/AC-Hz) | Phases (No.) | Comments |
|----------------------------|-------------|-------------|-----------|----------------------|--------------|----------|
| 1 | 110 | -- | -- | 60 | 1 | None |
| 2 | 230 | -- | -- | 50 | 1 | None |
| 3 | 110 | -- | -- | 50 | 1 | None |
| 4 | 230 | -- | -- | 60 | 1 | None |
| Supplementary information: | | | | | | |

1.2 EUT Operation Modes:

| Mode # | Description |
|--------|-----------------------------|
| 1 | Standby |
| 2 | Operative (movement cycles) |
| 3 | Manual switching |

1.3 EUT Configuration Modes

| Mode # | Description |
|--------|-------------|
| 1 | 110V; 60Hz |
| 2 | 230V; 50Hz |
| 3 | 110V; 50Hz |
| 4 | 230V; 60Hz |

Supplementary information:

Only mentioned configuration modes applied to perform the tests

1.4 Immunity Performance Criteria

Medical Equipment Performance Criteria - unacceptable operating conditions / responses are:

- component failures;
- changes in programmable parameters;
- reset to factory defaults (manufacturer's presets);
- change of operating mode;
- false alarms;
- cessation or interruption of any intended operation, even if accompanied by an alarm;
- initiation of any unintended operation, including unintended or uncontrolled motion, even if accompanied by an alarm;
- error of a displayed numerical value sufficiently large to affect diagnosis or treatment;
- noise on a waveform in which the noise is indistinguishable from physiologically-produced signals or the noise interferes with interpretation of physiologically-produced signals;
- artefact or distortion in an image in which the artefact is indistinguishable from physiologically-produced signals or the distortion interferes with interpretation of physiologically-produced signals;
- failure of automatic diagnosis or treatment EQUIPMENT and SYSTEMS to diagnose or treat, even if accompanied by an alarm.

Medical Specific Compliance Criteria for the Voltage Dips and Interruptions Test:

Clause 6.2.7.1 b) - the equipment is allowed a deviation from the requirements of 6.2.1.10 at the immunity levels specified in Table 11 (<5% / >95% / 5s), provided the equipment remains safe, experiences no component failures and is restorable to the pre-test state with operator intervention.

The equipment has not essential performance.

1.5 Compliance Summary

| IEC 60601-1-2 | | | |
|---------------|--|---|----------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 5 | Identification, Marking And Documents | | P |
| 5.1 | Marking on the outside | | N/A |
| 5.1.1 | RF equipment marked with symbol IEC 60417-5140 for non-ionizing radiation. |  | N/A |
| 5.1.2 | Equipment for which the connector testing exemption is used marked with symbol IEC 60417-5134 |  | N/A |
| 5.1.3 | Equipment specified for use only in shielded location has appropriate marking/warning labels | | N/A |
| 5.2 | Accompanying documents | | P |
| 5.2.1 | Instructions for use | | P |
| 5.2.1.1 | All equipment and systems: | | P |
| a) | A statements that medical electrical equipment needs special precautions regarding EMC and needs to be installed according to EMC information | | P |
| b) | A statement that mobile RF communications equipment can effect medical electrical equipment | | P |
| 5.2.1.2 | Equipment for which the connector testing exemption is used | | N/A |
| a) | A reproduction of the ESD warning symbol (IEC 60417-5134) |  | N/A |
| b) | A warning that pins of connectors marked with the warning symbol shall not be touched and connections shall not be made without special precautions | | N/A |
| c) | A specification of ESD precautionary procedures | | N/A |
| d) | A recommendation that all staff receive explanation and training in ESD procedures | | N/A |
| e) | A specification of the minimum contents of ESD precautions procedure training | | N/A |
| 5.2.1.3 | For equipment and systems without a manual sensitivity adjustment and for which the manufacturer specifies a minimum amplitude or value: | | N/A |
| a) | The minimum amplitude or value of signal | | N/A |
| b) | A warning that operation of the equipment below that value may cause inaccurate results | | N/A |
| 5.2.1.4 | For Type A Professional ME Equipment intended for use in domestic establishment instructions for use includes a warning: This ME equipment is intended for use by professional healthcare personnel only. | | N/A |

| IEC 60601-1-2 | | | |
|---------------|---|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 5.2.2 | Technical description | | P |
| 5.2.2.1 | Requirement for all ME equipment and systems: | | P |
| a) | List of cables and accessories | | P |
| b) | A warning that other cables and accessories may negatively affect EMC performance | | P |
| c) | Table 1, modified as appropriate using Fig. 1 and 2 | | P |
| d) | A warning regarding stacking and location close to other equipment | | P |
| e) | A justification for each immunity compliance level below 60601 test level | | N/A |
| f) | Table 2, completed as appropriate using Figure 3 | | P |
| g) | The essential performance of ME equipment | | N/A |
| 5.2.2.2 | ME Equipment not specified for use in shielded location | | P |
| | Tables 3 and 5 (life-supporting) using Figure 4, Tables 4 and 6 (non-life-supporting) using Figure 5 selected and completed as appropriate following a)-e) | | P |
| 5.2.2.3 | ME Equipment specified for use only in shielded location | | N/A |
| a) | A warning that equipment should be used only in the specified type of shielded location | | N/A |
| b) | Tables modified if disturbance allowance according to 6.1.1.1 d) is used | | N/A |
| c) | A specification of allowed emission of other equipment located within the shielded location | | N/A |
| d) | Table 7 (life-supporting) or 8 (non-life-supporting) as appropriate | | N/A |
| 5.2.2.4 | ME Equipment that intentionally apply RF energy – documents shall include guidelines for avoiding or identifying and resolving adverse electromagnetic effects on other equipment | | N/A |
| 5.2.2.5 | ME Equipment that intentionally receive RF energy | | N/A |
| a) | Each (preferred if applicable) frequency or frequency band of reception, and the bandwidth of the receiving section of the ME equipment in those bands | | N/A |
| b) | A warning that the ME equipment may be interfered with by other equipment | | N/A |
| 5.2.2.6 | ME Equipment that includes RF transmitters – documentation shall include each frequency or frequency band of transmission, the type and frequency characteristics of the modulation and ERD | | N/A |
| 5.2.2.7 | Requirements of cables, transducers and accessories | | P |
| a) | Documentation shall include list of ME Equipment | | P |
| b) | A warning that use of other accessories results in non-compliance | | P |

| IEC 60601-1-2 | | | |
|---------------|--|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |
| 5.2.2.8 | Requirements applicable to large permanently installed ME equipment and systems | | N/A |
| a) | A statement that an exemption has been used and that the me equipment has not been tested for radiated RF immunity over the entire frequency range 80 MHz to 2,5 GHz | | N/A |
| b) | A warning that the ME equipment has been tested for radiated RF immunity only at selected frequencies | | N/A |
| c) | A list of the transmitters or equipment used as RF test sources and the frequency and modulation characteristics of each source. | | N/A |
| 5.2.2.9 | Requirements applicable to ME equipment that has no essential performance | | P |
| a) | Statement that the ME equipment was not tested for immunity to electromagnetic disturbances | | N/A |
| b) | Document shall include information applicable to the me equipment | | P |
| 5.2.2.10 | Requirements applicable to ME equipment that is Type A Professional only | | N/A |
| | Document include a justification for not complying with the CISPR 11 group 2 Class B electromagnetic radiation disturbance limit | | N/A |


1.6 Result Summary

| Clause | Requirement – Test | Result/Comments | Verdict P / F / N/A |
|---|---|-----------------------------------|------------------------|
| 6.1 | Emissions | | P |
| 6.1.1.1 | Classification | | — |
| | Class A or B.....: | A | — |
| | Group 1 or 2.....: | 1 | — |
| | CISPR 11, 22, 14-1, or 15 | CISPR 11 | — |
| 6.1.1.2 | Limits of mains terminal disturbance voltage | | P |
| | Limits for radiated disturbance | | P (*) |
| | Limits for disturbance power (if applicable) | | N/A |
| 6.1.3.1 | Harmonic Current Emissions per IEC61000-3-2 | | P |
| 6.1.3.2 | Voltage Fluctuations and Flicker per IEC61000-3-3.....: | | P |
| 6.2 | Immunity | | P |
| 6.2.2 | Electrostatic Discharges (ESD) | It has not essential performance. | P |
| 6.2.3 | Radiated RF electromagnetic Fields | It has not essential performance. | P |
| 6.2.4 | Electrical Fast Transients and bursts | It has not essential performance. | P |
| 6.2.5 | Surges | It has not essential performance. | P |
| 6.2.6 | Conducted Disturbances, induced by RF fields | It has not essential performance. | P |
| 6.2.7 | Voltage Dips, Interruptions, and variations.....: | It has not essential performance. | P |
| 6.2.8 | Power-frequency Magnetic Field | It has not essential performance. | P |
| Supplementary information: | | | |
| (*) Radiated emission test, out of accreditation scope: ENAC N° 5/LE011 | | | |

1.7 Test Conditions and Results – Conducted Emissions

| | | | | |
|--|---|---|----------------|--------------------------|
| CISPR 11 | TEST: Limits of mains terminal disturbance voltage | | | Verdict |
| <p><u>Method:</u> The AMN placed 0,8 m from the boundary of the unit under test and bonded to a ground reference plane. This distance was between the closest points of the AMN and the EUT. All other units of the EUT and associated equipment were at least 0,8 m from the AMN. All power was connected to the system through Artificial Mains Network (AMN). Conducted voltage measurements on mains lines were made at the output of the AMN.</p> | | | | P |
| Laboratory Parameters | | Required prior to the test | | During the test |
| Ambient Temperature | | 10 to 40 °C | | 23°C |
| Relative Humidity | | 10 to 90 % | | 31% |
| Fully configured sample scanned over the following frequency range | | Frequency range on each side of line | | Measurement Point |
| | | 150kHz to 30MHz | | Mains |
| Equipment mode | | Power interface mode | | 2 |
| | | EUT configurations mode | | 2 |
| | | Operation mode | | 1 & 2 |
| Limits – Group 1 - Class A | | | | |
| Frequency (MHz) | Limit dB (µV) | | | |
| | Quasi-Peak | Result | Average | Result |
| 0.15 to 0.50 | 79 | P | 66 | P |
| 0.50 to 30 | 73 | P | 60 | P |
| Supplementary information: | | | | |
| Warning: | | | | |
| This is an equipment in Class A. In a domestic environment this equipment may cause radio interference, in which case it may require that the user can take appropriate actions. | | | | |

| Test Equipment Used | | | | | |
|----------------------------|--------------------|---------------------|--------------|------------------|-----------------|
| Used | Description | Manufacturer | Model | Cal. Date | Cal. Due |
| X | EMI Receiver | PMM | 9010 | 21/12/2015 | 21/12/2016 |
| X | LISN | ROHDE & SCHWARZ | ESH2-Z5 | 20/06/2016 | 20/06/2017 |
| X | Pulse Limiter | ROHDE & SCHWARZ | ESH3-Z2 | 20/02/2015 | 20/02/2017 |
| Supplementary information: | | | | | |



| Tabulated Results for Mains Terminal Disturbance Voltage | | | | |
|--|-------------------|--------------|----------------|--------------|
| Frequency (MHz) | Quasi Peak (dBµV) | Limit (dBµV) | Average (dBµV) | Limit (dBµV) |
| | | | | |
| | | | | |
| | | | | |

Supplementary information: See graphics below


Graphical representation of Mains Terminal Disturbance Voltage Measurement

Op. Cond.: EQUIPMENT IN STANDBY MODE

Limits.: QUASIPEAK limit (QP): red line AVERAGE limit (AV): yellow line

Comment: PHASE & NEUTRAL, sweeps QUASIPEAK (blue) and AV (red)

230 Vac / 50 Hz



Medical_iberica_cama_cond_standby

| Start [MHz] | Stop [MHz] | Step | Detector | Hold Time | RBW | Min Att | Pre Amp | Pre Sel | Prompt start | Ancillary |
|-------------|------------|--------------|---------------------------------|-----------|-------|---------|---------|---------|--------------|-----------|
| 0.15 | 30 | AUTO (5 kHz) | P Q A 55011.aqp 55011.aav | 20 ms | 9 kHz | 10 | ON | ON | ... | N, L1 |


Ancillary = General

Factors: QPeak Avg

Limits:

55011.aqp

55011.aav



Medical_iberica_cama_cond_standby

| Start [MHz] | Stop [MHz] | Step | Detector | Hold Time | RBW | Min Att | Pre Amp | Pre Sel | Prompt start | Ancillary |
|-------------|------------|--------------|---------------------------------|-----------|-------|---------|---------|---------|--------------|-----------|
| 0.15 | 30 | AUTO (5 kHz) | P Q A 55011.aqp 55011.aav | 20 ms | 9 kHz | 10 | ON | ON | ... | N, L1 |

Ancillary = General

Factors: QPeak Avg


Limits:

55011.aqp

55011.aav

Graphical representation of Mains Terminal Disturbance Voltage Measurement


Op. Cond.: EQUIPMENT IN OPERATIVE MODE (MOVEMENT CYCLES)
Limits.: QUASISPEAK limit (QP): red line AVERAGE limit (AV): yellow line
Comment: PHASE & NEUTRAL, sweeps QUASISPEAK (blue) and AV (red) 230 Vac / 50 Hz



Medical_iberica_cama_cond_op

| Start [MHz] | Stop [MHz] | Step | Detector | Hold Time | RBW | Min Att | Pre Amp | Pre Sel | Prompt start | Ancillary |
|-------------|------------|--------------|---------------------------------|-----------|-------|---------|---------|---------|--------------|-----------|
| 0.15 | 30 | AUTO (5 kHz) | P Q A 55011.aqp 55011.aav | 20 ms | 9 kHz | 10 | ON | ON | ... | N, L1 |

Ancillary = General Factors: QPeak
 Limits: 55011.aqp Avg
 55011.aav



Medical_iberica_cama_cond_op


| Start [MHz] | Stop [MHz] | Step | Detector | Hold Time | RBW | Min Att | Pre Amp | Pre Sel | Prompt start | Ancillary |
|-------------|------------|--------------|---------------------------------|-----------|-------|---------|---------|---------|--------------|-----------|
| 0.15 | 30 | AUTO (5 kHz) | P Q A 55011.aqp 55011.aav | 20 ms | 9 kHz | 10 | ON | ON | ... | N, L1 |

Ancillary = General Factors: QPeak
 Limits: 55011.aqp Avg
 55011.aav

1.8 Test Conditions and Results – Radiated Emissions

| | | | |
|---|--|---------------------------------|----------------|
| CISPR 11 | TEST: Limits for radiated disturbance 30 MHz –1 GHz | | Verdict |
| <p>Method: Measurements were made in a 10-meter semi-anechoic chamber or Open Area Test Site that complies to CISPR 16. Preliminary (peak) measurements were performed at an antenna to EUT separation distance of 10 meter. The EUT was rotated 360° about its azimuth with the receive antenna located at various heights in horizontal and vertical polarities. Final measurements (quasi-peak) were then performed by rotating the EUT 360° and adjusting the receive antenna height from 1 to 4 m. All frequencies were investigated in both horizontal and vertical antenna polarity, where applicable.</p> | | | P* |
| Laboratory Parameters: | Required prior to the test | During the test | |
| Ambient Temperature | 10 to 40 °C | 23°C | |
| Relative Humidity | 10 to 90 % | 31% | |
| Fully configured sample scanned over the following frequency range | Frequency range on each side of line | Measurement Point | |
| | 30MHz – 1GHz | 3 m measurement distance | |
| Equipment mode | Power interface mode | 2 | |
| | EUT configurations mode | 2 | |
| | Operation mode | 1 & 2 | |
| Limits – Group 1 Class A | | | |
| Frequency (MHz) | Limit dB (µV/m) | | |
| | Quasi-Peak | Results | |
| 30 to 230 | 40 + 10 = 50(**) | P | |
| 230 to 1000 | 47 + 10 = 57(**) | P | |
| Supplementary information: | | | |
| (*) Test outside the scope of accreditation ENAC N° 5/LE011 | | | |
| (**)The measurements corresponding to this test, have been performed at 3 meters of distance and the applied limits have been corrected according to the indications of clause 10.8 of the Standard EN 55022 where the following relation is indicated: $L2=L1 (d1/d2)$ where dn is a distance in meters and Ln is the limit in mV/m. | | | |
| Warning: | | | |
| This is an equipment in Class A. In a domestic environment this equipment may cause radio interference, in which case it may require that the user can take appropriate actions. | | | |

| Test Equipment Used | | | | | |
|----------------------------|--------------------|---------------------|--------------|------------------|-----------------|
| Used | Description | Manufacturer | Model | Cal. Date | Cal. Due |
| X | EMI Receiver | PMM | 9010 | 21/12/2015 | 21/12/2016 |
| X | EMI Receiver | PMM | 9060 | 21/12/2015 | 21/12/2016 |
| X | Bilog. Antenna | AH SYSTEMS | SAS-521F-7 | -- | -- |
| Supplementary information: | | | | | |




| Tabulated Results for Radiated Disturbance | | |
|--|---------------------------|----------------------|
| Frequency (MHz) | Quasi Peak (dB μ V/m) | Limit (dB μ V/m) |
| | | |

Supplementary information:
There are no levels next to the limit. See graphical representation below

Graphical representation of Radiated Disturbance Measurement

Op. Cond.: EQUIPMENT IN STANDBY MODE
Limits.: QUASIPEAK limit (QP): red line
Comment: VERTICAL POLARIZATION, LATERAL POSITION, sweep QPK (blue) 230 Vac / 50 Hz




Medical_iberica_cama_rad_stdby

| Start [MHz] | Stop [MHz] | Step | Detector | Hold Time | RBW | Min Att | Pre Amp | Pre Sel | Prompt start | Ancillary |
|-------------|------------|----------------|------------------|-----------|---------|---------|---------|---------|--------------|-----------|
| 30 | 1000 | AUTO (100 kHz) | P Q ind Limit10m | 10 ms | 120 kHz | 10 | ON | ON | ... | V, H |

Ancillary = Antenna
 Limits: ind Limit10m
 Factors: NONE QPeak

Op. Cond.: EQUIPMENT IN STANDBY MODE
Limits.: QUASIPEAK limit (QP): red line
Comment: HORIZONTAL POLARIZATION, LATERAL POSITION, sweep QPK (blue) 230 Vac / 50 Hz



Medical_iberica_cama_rad_stdby

| Start [MHz] | Stop [MHz] | Step | Detector | Hold Time | RBW | Min Att | Pre Amp | Pre Sel | Prompt start | Ancillary |
|-------------|------------|----------------|------------------|-----------|---------|---------|---------|---------|--------------|-----------|
| 30 | 1000 | AUTO (100 kHz) | P Q ind Limit10m | 10 ms | 120 kHz | 10 | ON | ON | ... | V, H |

Ancillary = Antenna
 Limits: ind Limit10m
 Factors: NONE QPeak

Graphical representation of Radiated Disturbance Measurement

Op. Cond.: EQUIPMENT IN OPERATIVE MODE (MOVEMENT CYCLES)
Limits.: QUASIPeAK limit (QP): red line
Comment: VERTICAL POLARIZATION, LATERAL POSITION, sweep QPK (blue) 230 Vac / 50 Hz



Medical_iberica_cama_rad_op

| Start [MHz] | Stop [MHz] | Step | Detector | Hold Time | RBW | Min Att | Pre Amp | Pre Sel | Prompt start | Ancillary |
|-------------|------------|----------------|------------------|-----------|---------|---------|---------|---------|--------------|-----------|
| 30 | 1000 | AUTO (100 kHz) | P Q ind Limit10m | 10 ms | 120 kHz | 10 | ON | ON | ... | V, H |

Ancillary = Antenna
 Limits: ind Limit10m
 Factors: NONE
 QPeak

Op. Cond.: EQUIPMENT IN OPERATIVE MODE (MOVEMENT CYCLES)
Limits.: QUASIPeAK limit (QP): red line
Comment: HORIZONTAL POLARIZATION, LATERAL POSITION, sweep QPK (blue) 230 Vac / 50 Hz



Medical_iberica_cama_rad_op

| Start [MHz] | Stop [MHz] | Step | Detector | Hold Time | RBW | Min Att | Pre Amp | Pre Sel | Prompt start | Ancillary |
|-------------|------------|----------------|------------------|-----------|---------|---------|---------|---------|--------------|-----------|
| 30 | 1000 | AUTO (100 kHz) | P Q ind Limit10m | 10 ms | 120 kHz | 10 | ON | ON | ... | V, H |

Ancillary = Antenna
 Limits: ind Limit10m
 Factors: NONE
 QPeak

1.9 Test Conditions and Results – Disturbance Power Emissions

| | | | | |
|---|--|-----------------------------------|--------------------------|----------------|
| CISPR 14-1 | TEST: Limits of disturbance power | | | Verdict |
| <p>Method: Measurements were made on a ground plane that extends 1-meter minimum beyond all sides of the system under test. All power was connected to the system through Line Impedance Stabilization Networks (LISN). The lead to be measured on is stretched in a straight line for a distance sufficient to accommodate the absorbing clamp, and to permit the necessary measuring adjustment of position for tuning. The clamp is placed around the lead so as to measure a quantity proportional to the disturbance on the lead.</p> | | | | N/A |
| Laboratory Parameters: | | Required prior to the test | During the test | |
| Ambient Temperature | | 15 to 35 °C | °C | |
| Relative Humidity | | 30 to 60 % | % | |
| Fully configured sample scanned over the following frequency range | | Frequency range | Measurement point | |
| | | 30 MHz to 300 MHz | Mains | |
| Equipment mode | | Power interface mode | | |
| | | EUT configurations mode | | |
| | | Operation mode | | |
| Limits disturbance power on terminals | | | | |
| Frequency | dB(pW) | | | |
| 30 – 300 MHz | Quasi-Peak | Result | Average | Result |
| Household and Tools < 700 W | 45 to 55 | | 35 to 45 | |
| 700 W < Tools < 1000 W | 49 to 59 | | 39 to 49 | |
| Tools >1000 W | 55 to 65 | | 45 to 55 | |
| Supplementary information: | | | | |

| Test Equipment Used | | | | | |
|----------------------------|--------------------|---------------------|--------------|------------------|-----------------|
| Used | Description | Manufacturer | Model | Cal. Date | Cal. Due |
| | | | | | |

Supplementary information:

| Test setup for Disturbance Power Emissions | |
|---|--|
| | |

| Tabulated Results for Disturbance Power Emissions | | | | | | | |
|--|-----------------------------|----------------------------|------------------------------|------------------------------|-----------------------|-----------------------|--------------------|
| Test Frequency (MHz) | Meter Reading dB(µV) | Detector (Pk/QP/Av) | Gain/Loss Factor (dB) | Transducer Factor(dB) | Level dB(µV/m) | Limit dB(µV/m) | Margin (dB) |
| | | | | | | | |


| Graphical representation of Disturbance Power Emissions Measurement | |
|--|--|
| | |

1.10 Test Conditions and Results – Limits for Harmonic Current Emissions

| | | |
|---|--|------------------------|
| 61000-3-2 | TEST: Limits for Harmonic current emissions (IEC 61000-3-2: use latest ed.) | Verdict |
| <p>Method: This test consists on the measurement of harmonics components of the input current which may be produced by equipment having an input current up to and including 16 A per phase, and intended to be connected to public low-voltage distribution systems. The equipment is tested under specified conditions of operation.</p> | | P |
| Laboratory Parameters: | Required prior to the test | During the test |
| Ambient Temperature | 15 to 35 °C | 25°C |
| Relative Humidity | 30 to 60 % | 34 % |
| Equipment mode | Power interface mode | 2 |
| | EUT configurations modes | 2 |
| | Operation modes | 1 & 2 |
| Classification of Equipment..... : | | Class A |
| <p>Supplementary information: According applied Standard, clause 1, for systems with nominal voltage less than 220V (phase-neutral), the limits have not yet been considered. Due to this, the test only has been performed at 230 V / 50 Hz.</p> | | |

| Test Equipment Used | | | | | |
|----------------------------|--------------------|---------------------|--------------|------------------|-----------------|
| Used | Description | Manufacturer | Model | Cal. Date | Cal. Due |
| X | AC Power supply | PACIFIC | 360-AMX | 13/07/2015 | 13/07/2017 |
| X | Power analyser | VOLTECH | IEC555 | 27/11/2015 | 27/11/2016 |

Supplementary information:




| Tabulated Results for Harmonic Current Emissions | | |
|---|---------------------|----------------------------------|
| Op. Cond.: EQUIPMENT IN STANDBY MODE | | |
| Product: CAMA HOSPITALARIA Serial no: -- Description: STANDBY 2416/0524 JCC Test Date: 21 Jul 2016 13:45 Result Name: M. IBERICA/GALAXY2-- | | 01 Aug 2016 14:15 Page 1 of 1 |
| Type of Test: EN61000:2001 Harmonics Limits: Class A Power Analyzer: Voltech PM3000A v2.20 s/n 0723 AC Source: Mains / Manual Source | | |
| Harmonic Results Against Chosen Limits: <div style="text-align: center; font-size: 2em; color: green; font-weight: bold;">PASS</div> | Notes: | |
| Test Parameter Details | User Entered | Measured |
| Operating Frequency: | 50 | 49.9922 |
| Operating Voltage: | 230 | 230.9808 |
| Specified Power: | 0.0000 | 7.5762 |
| Fundamental Current: | 0.0000 | 0.0385 |
| Power Factor: | 0.0000 | 0.3118 |
| Average Input Current: | | 0.1040 |
| Maximum POHC: | | 0.0426 |
| POHC Limit: | | 0.2514 |
| Maximum THC: | | 0.0978 |
| Minimum Power: | 75 | |
| Class Multiplier: | 1.0000 | |
| Test Duration: | 00:02:30 | |

Tabulated Results for Harmonic Current Emissions

Op. Cond.: EQUIPMENT IN STANDBY MODE

| | | |
|--|--|-------------------|
| Product: | CAMA HOSPITALARIA | 01 Aug 2016 14:15 |
| Serial no: | -- | Page 1 of 1 |
| Description: | STANDBY 2416/0524 JCC | |
| Result Name: | M. IBERICA/GALAXY2-- | |
| Voltech IEC1000-3 Windows Software 3.11.07 | Test Date: | 21 Jul 2016 13:45 |
| Type of Test: | Fluctuating Harmonics Test - Single Harmonic Plot (2001) | |
| Power Analyzer: | Voltech PM3000A v2.20 s/n 0723 | |
| AC Source: | Mains / Manual Source | |
| Overall Result: | PASS | |




Tabulated Results for Harmonic Current Emissions

Op. Cond.: EQUIPMENT IN STANDBY MODE

| | | |
|--|---|-------------------|
| Product: | CAMA HOSPITALARIA | 01 Aug 2016 14:15 |
| Serial no: | -- | Page 1 of 1 |
| Description: | STANDBY 2416/0524 JCC | |
| Result Name: | M. IBERICA/GALAXY2-- | |
| Voltech IEC1000-3 Windows Software 3.11.07 | Test Date: | 21 Jul 2016 13:45 |
| Type of Test: | Fluctuating Harmonics Test - Normalised Worst Case Bar Chart (2001) | |
| Power Analyzer: | Voltech PM3000A v2.20 s/n 0723 | |
| AC Source: | Mains / Manual Source | |
| Overall Result: | PASS | |

| | |
|------------------|---------|
| Class | Class A |
| Class Multiplier | 1 |



Tabulated Results for Harmonic Current Emissions

Op. Cond.: EQUIPMENT IN STANDBY MODE

| | | |
|--|--|------------------------------|
| Product: | CAMA HOSPITALARIA | 01 Aug 2016 14:16 |
| Serial no: | -- | Page 1 of 1 |
| Description: | STANDBY 2416/0524 JCC | |
| Result Name: | M. IBERICA/GALAXY2-- | |
| Voltech IEC1000-3 Windows Software 3.11.07 | | Test Date: 21 Jul 2016 13:45 |
| Type of Test: | Fluctuating Harmonics Test - Source Qualification (2001) | |
| Power Analyzer: | Voltech PM3000A v2.20 s/n 0723 | |
| AC Source: | Mains / Manual Source | |
| Overall Result: | PASS | |

| | Nominal | Measured | Deviation | Allowed Deviation | Result |
|------------------|---------|----------|-----------|-------------------|--------|
| Supply Voltage | 230.00V | 230.98V | 0.98V | 4.60V | Pass |
| Supply Frequency | 50.00Hz | 49.99Hz | 0.01Hz | 0.25Hz | Pass |

| Harmonic | Reading | Limit | Result | Harmonic | Reading | Limit | Result |
|----------|---------|-------|--------|----------|---------|-------|--------|
| 2 | 0.03% | 0.20% | Pass | 3 | 0.03% | 0.90% | Pass |
| 4 | 0.03% | 0.20% | Pass | 5 | 0.03% | 0.40% | Pass |
| 6 | 0.03% | 0.20% | Pass | 7 | 0.03% | 0.30% | Pass |
| 8 | 0.03% | 0.20% | Pass | 9 | 0.03% | 0.20% | Pass |
| 10 | 0.03% | 0.20% | Pass | 11 | 0.03% | 0.10% | Pass |
| 12 | 0.03% | 0.10% | Pass | 13 | 0.03% | 0.10% | Pass |
| 14 | 0.03% | 0.10% | Pass | 15 | 0.03% | 0.10% | Pass |
| 16 | 0.03% | 0.10% | Pass | 17 | 0.03% | 0.10% | Pass |
| 18 | 0.03% | 0.10% | Pass | 19 | 0.03% | 0.10% | Pass |
| 20 | 0.03% | 0.10% | Pass | 21 | 0.03% | 0.10% | Pass |
| 22 | 0.03% | 0.10% | Pass | 23 | 0.03% | 0.10% | Pass |
| 24 | 0.03% | 0.10% | Pass | 25 | 0.03% | 0.10% | Pass |
| 26 | 0.03% | 0.10% | Pass | 27 | 0.03% | 0.10% | Pass |
| 28 | 0.03% | 0.10% | Pass | 29 | 0.03% | 0.10% | Pass |
| 30 | 0.03% | 0.10% | Pass | 31 | 0.03% | 0.10% | Pass |
| 32 | 0.03% | 0.10% | Pass | 33 | 0.03% | 0.10% | Pass |
| 34 | 0.03% | 0.10% | Pass | 35 | 0.03% | 0.10% | Pass |
| 36 | 0.03% | 0.10% | Pass | 37 | 0.03% | 0.10% | Pass |
| 38 | 0.03% | 0.10% | Pass | 39 | 0.03% | 0.10% | Pass |
| 40 | 0.03% | 0.10% | Pass | | | | |

Tabulated Results for Harmonic Current Emissions

Op. Cond.: EQUIPMENT IN STANDBY MODE

| | | |
|--|--|------------------------------|
| Product: | CAMA HOSPITALARIA | 01 Aug 2016 14:16 |
| Serial no: | -- | Page 1 of 1 |
| Description: | STANDBY 2416/0524 JCC | |
| Result Name: | M. IBERICA/GALAXY2-- | |
| Voltech IEC1000-3 Windows Software 3.11.07 | | Test Date: 21 Jul 2016 13:45 |
| Type of Test: | Fluctuating Harmonics Test - Worst Case Table (2001) | |
| Power Analyzer: | Voltech PM3000A v2.20 s/n 0723 | |
| AC Source: | Mains / Manual Source | |
| Overall Result: | PASS | |

| | |
|------------------|---------|
| Class | Class A |
| Class Multiplier | 1 |

| Harm | Limit 1 | Limit 2 | Average Reading | <L1 <L2 | Max Reading | <L2 | Pass FAIL | Harm | Limit 1 | Limit 2 | Average Reading | <L1 <L2 | Max Reading | <L2 | Pass FAIL |
|------|---------|---------|-----------------|---------|-------------|-----|-----------|------|---------|---------|-----------------|---------|-------------|-----|-----------|
| 2 | 1.0800A | 1.6200A | 1.982mA | ✓ ✓ | 3.726mA | ✓ | N/A | 3 | 2.3000A | 3.4500A | 32.94mA | ✓ ✓ | 33.54mA | ✓ | Pass |
| 4 | 430.0mA | 645.0mA | 1.806mA | ✓ ✓ | 3.726mA | ✓ | N/A | 5 | 1.1400A | 1.7100A | 31.85mA | ✓ ✓ | 33.51mA | ✓ | Pass |
| 6 | 300.0mA | 450.0mA | 1.607mA | ✓ ✓ | 3.705mA | ✓ | N/A | 7 | 770.0mA | 1.1550A | 31.06mA | ✓ ✓ | 31.18mA | ✓ | Pass |
| 8 | 230.0mA | 345.0mA | 1.741mA | ✓ ✓ | 3.726mA | ✓ | N/A | 9 | 400.0mA | 600.0mA | 30.85mA | ✓ ✓ | 31.05mA | ✓ | Pass |
| 10 | 184.0mA | 276.0mA | 1.700mA | ✓ ✓ | 3.717mA | ✓ | N/A | 11 | 330.0mA | 495.0mA | 28.66mA | ✓ ✓ | 29.92mA | ✓ | Pass |
| 12 | 153.3mA | 230.0mA | 1.760mA | ✓ ✓ | 3.726mA | ✓ | N/A | 13 | 210.0mA | 315.0mA | 28.34mA | ✓ ✓ | 28.57mA | ✓ | Pass |
| 14 | 131.4mA | 197.1mA | 1.634mA | ✓ ✓ | 3.706mA | ✓ | N/A | 15 | 150.0mA | 225.0mA | 26.08mA | ✓ ✓ | 26.19mA | ✓ | Pass |
| 16 | 115.0mA | 172.5mA | 1.363mA | ✓ ✓ | 3.020mA | ✓ | N/A | 17 | 132.3mA | 198.5mA | 23.67mA | ✓ ✓ | 24.56mA | ✓ | Pass |
| 18 | 102.2mA | 153.3mA | 1.247mA | ✓ ✓ | 1.538mA | ✓ | N/A | 19 | 118.4mA | 177.6mA | 22.45mA | ✓ ✓ | 23.60mA | ✓ | Pass |
| 20 | 92.00mA | 138.0mA | 1.242mA | ✓ ✓ | 1.242mA | ✓ | N/A | 21 | 107.1mA | 160.7mA | 20.96mA | ✓ ✓ | 21.11mA | ✓ | Pass |
| 22 | 83.63mA | 125.4mA | 1.242mA | ✓ ✓ | 1.242mA | ✓ | N/A | 23 | 97.82mA | 146.7mA | 18.63mA | ✓ ✓ | 18.63mA | ✓ | Pass |
| 24 | 76.66mA | 115.0mA | 1.242mA | ✓ ✓ | 1.242mA | ✓ | N/A | 25 | 90.00mA | 135.0mA | 16.14mA | ✓ ✓ | 16.14mA | ✓ | Pass |
| 26 | 70.76mA | 106.1mA | 1.242mA | ✓ ✓ | 1.242mA | ✓ | N/A | 27 | 83.33mA | 125.0mA | 13.82mA | ✓ ✓ | 15.92mA | ✓ | Pass |
| 28 | 65.71mA | 98.57mA | 1.242mA | ✓ ✓ | 1.242mA | ✓ | N/A | 29 | 77.58mA | 116.3mA | 12.38mA | ✓ ✓ | 13.66mA | ✓ | Pass |
| 30 | 61.33mA | 92.00mA | 1.242mA | ✓ ✓ | 1.242mA | ✓ | N/A | 31 | 72.58mA | 108.8mA | 11.18mA | ✓ ✓ | 11.18mA | ✓ | Pass |
| 32 | 57.50mA | 86.25mA | 1.242mA | ✓ ✓ | 1.242mA | ✓ | N/A | 33 | 68.18mA | 102.2mA | 8.695mA | ✓ ✓ | 8.695mA | ✓ | Pass |
| 34 | 54.11mA | 81.17mA | 1.242mA | ✓ ✓ | 1.242mA | ✓ | N/A | 35 | 64.28mA | 96.42mA | 6.512mA | ✓ ✓ | 8.566mA | ✓ | Pass |
| 36 | 51.11mA | 76.66mA | 1.242mA | ✓ ✓ | 1.242mA | ✓ | N/A | 37 | 60.81mA | 91.21mA | 6.207mA | ✓ ✓ | 6.211mA | ✓ | Pass |
| 38 | 48.42mA | 72.63mA | 1.242mA | ✓ ✓ | 1.242mA | ✓ | N/A | 39 | 57.69mA | 86.53mA | 3.726mA | ✓ ✓ | 3.726mA | ✓ | N/A |
| 40 | 46.00mA | 69.00mA | 1.242mA | ✓ ✓ | 1.242mA | ✓ | N/A | | | | | | | | |

<L1 : Reading is below limit 1.


<L2 : Reading is below limit 2.

N/A : Harmonic current below 0.6% of rated current or 5mA, whichever is greater, are disregarded.

Tabulated Results for Harmonic Current Emissions

Op. Cond.: EQUIPMENT IN STANDBY MODE

| | |
|--|------------------------------|
| Product: CAMA HOSPITALARIA | 01 Aug 2016 14:17 |
| Serial no: -- | Page 1 of 1 |
| Description: STANDBY 2416/0524 JCC | |
| Result Name: M. IBERICA/GALAXY2 | |
| Voltech IEC1000-3 Windows Software 3.11.07 | Test Date: 21 Jul 2016 13:09 |
| Type of Test: Waveform | |
| Power Analyzer: Voltech PM3000A v2.20 s/n 0723 | |
| AC Source: Mains / Manual Source | |
| | |




| Tabulated Results for Harmonic Current Emissions | | |
|---|---------------------|----------------------------------|
| Op. Cond.: EQUIPMENT IN OPERATIVE MODE | | |
| Product: CAMA HOSPITALARIA Serial no: -- Description: OPERATIVO (CICLOS SUBIDA/BAJADA) 2416/0524 JCC Test Date: 21 Jul 2016 13:39 Result Name: M. IBERICA/GALAXY2- | | 01 Aug 2016 14:11 Page 1 of 1 |
| Type of Test: EN61000:2001 Harmonics Limits: Class A Power Analyzer: Voltech PM3000A v2.20 s/n 0723 AC Source: Mains / Manual Source | | |
| Harmonic Results Against Chosen Limits: <div style="text-align: center; font-size: 2em; color: green; font-weight: bold;">PASS</div> | Notes: | |
| Test Parameter Details | User Entered | Measured |
| Operating Frequency: | 50 | 49.9922 |
| Operating Voltage: | 230 | 228.7659 |
| Specified Power: | 0.0000 | 152.0078 |
| Fundamental Current: | 0.0000 | 0.6826 |
| Power Factor: | 0.0000 | 0.4874 |
| Average Input Current: | | 0.4687 |
| Maximum POHC: | | 0.2023 |
| POHC Limit: | | 0.2514 |
| Maximum THC: | | 1.1814 |
| Minimum Power: | 75 | |
| Class Multiplier: | 1.0000 | |
| Test Duration: | 00:02:30 | |

Tabulated Results for Harmonic Current Emissions

Op. Cond.: EQUIPMENT IN OPERATIVE MODE

| | | |
|--|--|-------------------|
| Product: | CAMA HOSPITALARIA | 01 Aug 2016 14:12 |
| Serial no: | -- | Page 1 of 1 |
| Description: | OPERATIVO (CICLOS SUBIDA/BAJADA) 2416/0524 JCC | |
| Result Name: | M. IBERICA/GALAXY2- | |
| Voltech IEC1000-3 Windows Software 3.11.07 | Test Date: | 21 Jul 2016 13:39 |
| Type of Test: | Fluctuating Harmonics Test - Single Harmonic Plot (2001) | |
| Power Analyzer: | Voltech PM3000A v2.20 s/n 0723 | |
| AC Source: | Mains / Manual Source | |
| Overall Result: | PASS | |

Fundamental




Tabulated Results for Harmonic Current Emissions

Op. Cond.: EQUIPMENT IN OPERATIVE MODE

| | | |
|--|---|-------------------|
| Product: | CAMA HOSPITALARIA | 01 Aug 2016 14:12 |
| Serial no: | -- | Page 1 of 1 |
| Description: | OPERATIVO (CICLOS SUBIDA/BAJADA) 2416/0524 JCC | |
| Result Name: | M. IBERICA/GALAXY2- | |
| Voltech IEC1000-3 Windows Software 3.11.07 | Test Date: | 21 Jul 2016 13:39 |
| Type of Test: | Fluctuating Harmonics Test - Normalised Worst Case Bar Chart (2001) | |
| Power Analyzer: | Voltech PM3000A v2.20 s/n 0723 | |
| AC Source: | Mains / Manual Source | |
| Overall Result: | PASS | |

| | |
|------------------|---------|
| Class | Class A |
| Class Multiplier | 1 |



Tabulated Results for Harmonic Current Emissions

Op. Cond.: EQUIPMENT IN OPERATIVE MODE

| | | |
|------------------------------------|--|------------------------------|
| Product: | CAMA HOSPITALARIA | 01 Aug 2016 14:13 |
| Serial no: | -- | Page 1 of 1 |
| Description: | OPERATIVO (CICLOS SUBIDA/BAJADA) 2416/0524 JCC | |
| Result Name: | M. IBERICA/GALAXY2- | |
| Voltech IEC1000-3 Windows Software | 3.11.07 | Test Date: 21 Jul 2016 13:39 |
| Type of Test: | Fluctuating Harmonics Test - Source Qualification (2001) | |
| Power Analyzer: | Voltech PM3000A v2.20 s/n 0723 | |
| AC Source: | Mains / Manual Source | |
| Overall Result: | PASS | |

| | Nominal | Measured | Deviation | Allowed Deviation | Result |
|------------------|---------|----------|-----------|-------------------|--------|
| Supply Voltage | 230.00V | 228.77V | 1.23V | 4.60V | Pass |
| Supply Frequency | 50.00Hz | 49.99Hz | 0.01Hz | 0.25Hz | Pass |

| Harmonic | Reading | Limit | Result | Harmonic | Reading | Limit | Result |
|----------|---------|-------|--------|----------|---------|-------|--------|
| 2 | 0.03% | 0.20% | Pass | 3 | 0.03% | 0.90% | Pass |
| 4 | 0.03% | 0.20% | Pass | 5 | 0.03% | 0.40% | Pass |
| 6 | 0.03% | 0.20% | Pass | 7 | 0.04% | 0.30% | Pass |
| 8 | 0.03% | 0.20% | Pass | 9 | 0.03% | 0.20% | Pass |
| 10 | 0.03% | 0.20% | Pass | 11 | 0.03% | 0.10% | Pass |
| 12 | 0.03% | 0.10% | Pass | 13 | 0.03% | 0.10% | Pass |
| 14 | 0.03% | 0.10% | Pass | 15 | 0.03% | 0.10% | Pass |
| 16 | 0.03% | 0.10% | Pass | 17 | 0.03% | 0.10% | Pass |
| 18 | 0.03% | 0.10% | Pass | 19 | 0.03% | 0.10% | Pass |
| 20 | 0.03% | 0.10% | Pass | 21 | 0.03% | 0.10% | Pass |
| 22 | 0.03% | 0.10% | Pass | 23 | 0.03% | 0.10% | Pass |
| 24 | 0.03% | 0.10% | Pass | 25 | 0.03% | 0.10% | Pass |
| 26 | 0.03% | 0.10% | Pass | 27 | 0.03% | 0.10% | Pass |
| 28 | 0.03% | 0.10% | Pass | 29 | 0.03% | 0.10% | Pass |
| 30 | 0.03% | 0.10% | Pass | 31 | 0.03% | 0.10% | Pass |
| 32 | 0.03% | 0.10% | Pass | 33 | 0.03% | 0.10% | Pass |
| 34 | 0.03% | 0.10% | Pass | 35 | 0.03% | 0.10% | Pass |
| 36 | 0.03% | 0.10% | Pass | 37 | 0.03% | 0.10% | Pass |
| 38 | 0.03% | 0.10% | Pass | 39 | 0.03% | 0.10% | Pass |
| 40 | 0.03% | 0.10% | Pass | | | | |

Tabulated Results for Harmonic Current Emissions

Op. Cond.: EQUIPMENT IN OPERATIVE MODE

| | | |
|--|--|-------------------|
| Product: | CAMA HOSPITALARIA | 01 Aug 2016 14:13 |
| Serial no: | -- | Page 1 of 1 |
| Description: | OPERATIVO (CICLOS SUBIDA/BAJADA) 2416/0524 JCC | |
| Result Name: | M. IBERICA/GALAXY2- | |
| Voltech IEC1000-3 Windows Software 3.11.07 | Test Date: 21 Jul 2016 13:39 | |
| Type of Test: | Fluctuating Harmonics Test - Worst Case Table (2001) | |
| Power Analyzer: | Voltech PM3000A v2.20 s/n 0723 | |
| AC Source: | Mains / Manual Source | |
| Overall Result: | PASS | |

| | |
|------------------|---------|
| Class | Class A |
| Class Multiplier | 1 |

| Harm | Limit 1 | Limit 2 | Average Reading | <L1 <L2 | Max Reading | <L2 | Pass FAIL | Harm | Limit 1 | Limit 2 | Average Reading | <L1 <L2 | Max Reading | <L2 | Pass FAIL |
|------|---------|---------|-----------------|---------|-------------|-----|-----------|------|---------|---------|-----------------|---------|-------------|-----|-----------|
| 2 | 1.0800A | 1.6200A | 2.584mA | ✓ ✓ | 6.076mA | ✓ | N/A | 3 | 2.3000A | 3.4500A | 276.2mA | ✓ ✓ | 647.6mA | ✓ | Pass |
| 4 | 430.0mA | 645.0mA | 2.296mA | ✓ ✓ | 6.025mA | ✓ | N/A | 5 | 1.1400A | 1.7100A | 257.5mA | ✓ ✓ | 579.6mA | ✓ | Pass |
| 6 | 300.0mA | 450.0mA | 2.205mA | ✓ ✓ | 5.900mA | ✓ | N/A | 7 | 770.0mA | 1.1550A | 231.1mA | ✓ ✓ | 493.2mA | ✓ | Pass |
| 8 | 230.0mA | 345.0mA | 2.147mA | ✓ ✓ | 5.578mA | ✓ | N/A | 9 | 400.0mA | 600.0mA | 201.4mA | ✓ ✓ | 402.8mA | ✓ | Pass |
| 10 | 184.0mA | 276.0mA | 2.068mA | ✓ ✓ | 5.345mA | ✓ | N/A | 11 | 330.0mA | 495.0mA | 171.7mA | ✓ ✓ | 323.6mA | ✓ | Pass |
| 12 | 153.3mA | 230.0mA | 1.977mA | ✓ ✓ | 5.236mA | ✓ | N/A | 13 | 210.0mA | 315.0mA | 142.1mA | ✓ ✓ | 252.7mA | ✓ | Pass |
| 14 | 131.4mA | 197.1mA | 1.923mA | ✓ ✓ | 4.914mA | ✓ | N/A | 15 | 150.0mA | 225.0mA | 115.4mA | ✓ ✓ | 190.6mA | ✓ | Pass |
| 16 | 115.0mA | 172.5mA | 1.871mA | ✓ ✓ | 4.584mA | ✓ | N/A | 17 | 132.3mA | 198.5mA | 94.42mA | ✓ ✓ | 144.4mA | ✓ | Pass |
| 18 | 102.2mA | 153.3mA | 1.747mA | ✓ ✓ | 4.137mA | ✓ | N/A | 19 | 118.4mA | 177.6mA | 79.15mA | ✓ ✓ | 119.8mA | ✓ | Pass |
| 20 | 92.00mA | 138.0mA | 1.627mA | ✓ ✓ | 3.577mA | ✓ | N/A | 21 | 107.1mA | 160.7mA | 66.12mA | ✓ ✓ | 109.0mA | ✓ | Pass |
| 22 | 83.63mA | 125.4mA | 1.530mA | ✓ ✓ | 3.125mA | ✓ | N/A | 23 | 97.82mA | 146.7mA | 53.81mA | ✓ ✓ | 98.16mA | ✓ | Pass |
| 24 | 76.66mA | 115.0mA | 1.407mA | ✓ ✓ | 2.685mA | ✓ | N/A | 25 | 90.00mA | 135.0mA | 42.46mA | ✓ ✓ | 85.65mA | ✓ | Pass |
| 26 | 70.76mA | 106.1mA | 1.371mA | ✓ ✓ | 2.468mA | ✓ | N/A | 27 | 83.33mA | 125.0mA | 32.30mA | ✓ ✓ | 70.75mA | ✓ | Pass |
| 28 | 65.71mA | 98.57mA | 1.345mA | ✓ ✓ | 2.413mA | ✓ | N/A | 29 | 77.58mA | 116.3mA | 24.47mA | ✓ ✓ | 55.57mA | ✓ | Pass |
| 30 | 61.33mA | 92.00mA | 1.320mA | ✓ ✓ | 2.078mA | ✓ | N/A | 31 | 72.58mA | 108.8mA | 19.68mA | ✓ ✓ | 40.00mA | ✓ | Pass |
| 32 | 57.50mA | 86.25mA | 1.312mA | ✓ ✓ | 1.907mA | ✓ | N/A | 33 | 68.18mA | 102.2mA | 17.52mA | ✓ ✓ | 31.44mA | ✓ | Pass |
| 34 | 54.11mA | 81.17mA | 1.294mA | ✓ ✓ | 1.757mA | ✓ | N/A | 35 | 64.28mA | 96.42mA | 16.57mA | ✓ ✓ | 30.70mA | ✓ | Pass |
| 36 | 51.11mA | 76.66mA | 1.281mA | ✓ ✓ | 1.578mA | ✓ | N/A | 37 | 60.81mA | 91.21mA | 15.86mA | ✓ ✓ | 28.46mA | ✓ | Pass |
| 38 | 48.42mA | 72.63mA | 1.273mA | ✓ ✓ | 1.501mA | ✓ | N/A | 39 | 57.69mA | 86.53mA | 14.25mA | ✓ ✓ | 24.76mA | ✓ | Pass |
| 40 | 46.00mA | 69.00mA | 1.267mA | ✓ ✓ | 1.500mA | ✓ | N/A | | | | | | | | |

<L1 : Reading is below limit 1.


<L2 : Reading is below limit 2.

N/A : Harmonic current below 0.6% of rated current or 5mA, whichever is greater, are disregarded.

Tabulated Results for Harmonic Current Emissions

Op. Cond.: EQUIPMENT IN OPERATIVE MODE


| | | |
|--|--|-------------------|
| Product: | CAMA HOSPITALARIA | 01 Aug 2016 14:18 |
| Serial no: | -- | Page 1 of 1 |
| Description: | OPERATIVO (CICLOS SUBIDA/BAJADA) 2416/0524 JCC | |
| Result Name: | M. IBERICA/GALAXY2-- | |
| Voltech IEC1000-3 Windows Software 3.11.07 | Test Date: | 21 Jul 2016 13:49 |
| Type of Test: | Waveform | |
| Power Analyzer: | Voltech PM3000A v2.20 s/n 0723 | |
| AC Source: | Mains / Manual Source | |
| | | |



1.11 Test Conditions and Results – Limitation of Voltage Fluctuations and Flicker

| | | | |
|--|---|------------------------|----------------|
| 61000-3-3 | TEST: Limitation of Voltage Fluctuations And Flicker (IEC 61000-3-3: - use latest edition) | | Verdict |
| Method: The test circuit consists of a test supply voltage, reference impedance, the equipment under test and a flicker meter compliant with IEC 60868. The equipment shall be tested in the condition in which the manufacturer supplies it. | | | P |
| Laboratory Parameters: | Required prior to the test | During the test | |
| Ambient Temperature | 15 to 35 °C | 26 °C | |
| Relative Humidity | 30 to 60 % | 32 % | |
| Equipment mode | Power interface modes | 2 | |
| | EUT configurations modes | 2 | |
| | Operation modes | 1, 2 & 3 | |
| Control Method of Equipment (see below)..... | | 1 & 2 | |
| 1 - without additional conditions | | | |
| 2 - switched manually, or switched automatically more frequently than twice per day, and also has either a delayed restart (the delay being not less than a few tens of seconds), or manual restart, after a power supply interruption. | | | |
| 3 - attended while in use (for example: hair dryers, vacuum cleaners, kitchen equipment such as mixers, garden equipment such as lawn mowers, portable tools such as electric drills), or switched on automatically, or is intended to be switched on manually, no more than twice per day, and also has either a delayed restart (the delay being not less than a few tens of seconds) or manual restart, after a power supply interruption. | | | |
| Supplementary information: According applied Standard, clause 1, for systems with nominal voltage less than 220V (phase-neutral), the limits have not yet been considered. Due to this, the test only has been performed at 230 V / 50 Hz. | | | |

| Test Equipment Used | | | | | |
|----------------------------|--------------------------|---------------------|--------------|------------------|-----------------|
| Used | Description | Manufacturer | Model | Cal. Date | Cal. Due |
| X | AC Power supply | PACIFIC | 360-AMX | 13/07/2015 | 13/07/2017 |
| X | Flicker meter | VOLTECH | PM3000A | 27/11/2015 | 27/11/2016 |
| X | Series impedance network | VOLTECH | IEC555 | 27/11/2015 | 27/11/2016 |
| Supplementary information: | | | | | |



| Tabulated Results for Voltage Fluctuations And Flicker | | | | | |
|--|---|------------------------------|--------|----------|-----------------|
| Op. Cond.: EQUIPMENT IN STANDBY MODE | | | | | |
| Product: CAMA HOSPITALARIA | | 01 Aug 2016 14:19 | | | |
| Serial no: -- | | Page 1 of 1 | | | |
| Description: STANDBY 2416/0524 JCC | | | | | |
| Result Name: M. IBERICA/GALAXY2-- | | | | | |
| Voltech IEC1000-3 Windows Software 3.11.07 | | Test Date: 21 Jul 2016 14:15 | | | |
| Type of Test: Flickermeter Test - Table | | | | | |
| Power Analyzer: Voltech PM3000A v2.20 s/n 0723 | | | | | |
| AC Source: Mains / Manual Source | | | | | |
| Overall Result: | Notes: | | | | |
| PASS | Plt test duration only 20 minutes Measurement method - Voltage | | | | |
| | | Plt | | | |
| Limit | 0.650 | | | | |
| Reading | 0.071 | | | | |
| | | Pst | dc (%) | dmax (%) | d(t) > 3.3%(ms) |
| Limit | 1.000 | 3.300 | 4.000 | 500 | |
| Reading 1 | 0.071 | 0.015 | 0.052 | 0 | |
| Reading 2 | 0.071 | 0.015 | 0.052 | 0 | |

| Tabulated Results for Voltage Fluctuations And Flicker | | | | | |
|---|---|------------------------------|--------|----------|-----------------|
| Op. Cond.: EQUIPMENT IN OPERATIVE MODE | | | | | |
| Product: CAMA HOSPITALARIA | | 01 Aug 2016 14:18 | | | |
| Serial no: -- | | Page 1 of 1 | | | |
| Description: OPERATIVO (CICLOS SUBIDA/BAJADA) 2416/0524 JCC | | | | | |
| Result Name: M. IBERICA/GALAXY2 | | | | | |
| Voltech IEC1000-3 Windows Software 3.11.07 | | Test Date: 21 Jul 2016 13:52 | | | |
| Type of Test: Flickermeter Test - Table | | | | | |
| Power Analyzer: Voltech PM3000A v2.20 s/n 0723 | | | | | |
| AC Source: Mains / Manual Source | | | | | |
| Overall Result: | Notes: | | | | |
| PASS | Plt test duration only 20 minutes Measurement method - Voltage | | | | |
| | | Plt | | | |
| Limit | 0.650 | | | | |
| Reading | 0.084 | | | | |
| | | Pst | dc (%) | dmax (%) | d(t) > 3.3%(ms) |
| Limit | 1.000 | 3.300 | 4.000 | 500 | |
| Reading 1 | 0.087 | 0.110 | 0.363 | 0 | |
| Reading 2 | 0.082 | 0.102 | 0.407 | 0 | |

Tabulated Results for Voltage Fluctuations And Flicker

Op. Cond.: MANUAL SWITCHING OPERATIONS

| | | |
|--|---|-------------------|
| Product: | CAMA HOSPITALARIA | 01 Aug 2016 14:19 |
| Serial no: | -- | Page 1 of 1 |
| Description: | OPERACIONES MANUALES (ON/OFF) 2416/0524 JCC | |
| Result Name: | M. IBERICA/GALAXY2 | |
| Voltech IEC1000-3 Windows Software 3.11.07 | Test Date: 22 Jul 2016 08:30 | |
| Type of Test: | Manual Switching - Table | |
| Power Analyzer: | Voltech PM3000A v2.20 s/n 0723 | |
| AC Source: | Mains / Manual Source | |
| Overall Result: | Notes: Measurement method - Voltage | |
| PASS | | |

| | |
|--------------|--------|
| Average dmax | 0.7773 |
| dmax limit | 6 |

| Result | dc | dt > dc | dmax | dmax pass / fail | included |
|--------|-------|---------|-------|------------------|----------|
| 1 | 0.117 | 0.000 | 0.334 | Pass | ✓ |
| 2 | 0.015 | 0.000 | 0.552 | Pass | ✓ |
| 3 | 0.102 | 0.000 | 0.516 | Pass | ✓ |
| 4 | 0.125 | 0.000 | 0.653 | Pass | ✓ |
| 5 | 0.015 | 0.000 | 0.996 | Pass | ✓ |
| 6 | 0.015 | 0.000 | 0.458 | Pass | ✓ |
| 7 | 0.015 | 0.000 | 0.975 | Pass | ✓ |
| 8 | 0.015 | 0.000 | 0.421 | Pass | ✓ |
| 9 | 0.015 | 0.000 | 0.842 | Pass | ✓ |
| 10 | 0.131 | 0.000 | 0.574 | Pass | ✓ |
| 11 | 0.139 | 0.000 | 0.836 | Pass | ✓ |
| 12 | 0.015 | 0.000 | 0.690 | Pass | ✓ |
| 13 | 0.015 | 0.000 | 1.237 | Pass | ✓ |
| 14 | 0.038 | 0.000 | 2.958 | Pass | ✗ |
| 15 | 0.015 | 0.000 | 1.033 | Pass | ✓ |
| 16 | 0.015 | 0.000 | 1.209 | Pass | ✓ |
| 17 | 0.015 | 0.000 | 0.442 | Pass | ✓ |
| 18 | 0.125 | 0.000 | 0.915 | Pass | ✓ |
| 19 | 0.015 | 0.000 | 0.305 | Pass | ✗ |
| 20 | 0.117 | 0.000 | 1.428 | Pass | ✓ |
| 21 | 0.015 | 0.000 | 0.465 | Pass | ✓ |
| 22 | 0.117 | 0.000 | 1.201 | Pass | ✓ |
| 23 | 0.096 | 0.000 | 0.887 | Pass | ✓ |
| 24 | 0.096 | 0.000 | 0.436 | Pass | ✓ |


1.12 Test Conditions and Results – Immunity to Electrostatic Discharges

| | | | |
|---|--|-----------------------------------|--|
| 61000-4-2 | TEST: Electrostatic discharges (IEC 61000-4-2: - use latest edition) | | Verdict |
| <p><u>Method:</u> The test is intended to demonstrate the immunity of equipment subjected to static electricity discharges from operators directly and to adjacent objects. The table top equipment under test is placed on a wooden table, 0.8 m high, standing on the ground reference plane. A horizontal coupling plane (HCP), 1.6 x 0.8 m, is placed on the table. The EUT and the cables are isolated from the coupling plane by an insulating support 0.5 mm thick. The floor standing equipment is isolated from the ground reference plane by an insulating support about 0.1 m thick. The vertical coupling plane (VCP) of dimensions 0.5 m x 0.5 m is placed parallel to, and positioned at a distance of 0.1 m from, the EUT.</p> | | | P |
| Laboratory Parameters: | | Required prior to the test | During the test |
| Ambient Temperature | | 15 to 35 °C | 25°C |
| Relative Humidity | | 30 to 60 % | 41% |
| Equipment mode | | Power interface mode | 2 |
| | | EUT configurations mode | 2 |
| | | Operation mode | 1 & 2 |
| Test Levels | | | |
| Discharge type | Discharge Level (kV) | | Number of discharges per location (each polarity) |
| | Positive | Negative | |
| Air – Direct | 2, 4, 8 | 2, 4, 8 | 10 |
| Contact – Direct | 2, 4, 6 | 2, 4, 6 | 10 |
| Contact – Indirect | 2, 4, 6 | 2, 4, 6 | 10 |
| Discharge location | <p>See photo documentation of the test set-up All external locations accessible by hand, Horizontal plate (HCP) Vertical coupling plate (VCP)</p> | | |
| Supplementary information: | | | |

| Test Equipment Used | | | | | |
|----------------------------|--|---------------------|--------------|------------------|-----------------|
| Used | Description | Manufacturer | Model | Cal. Date | Cal. Due |
| X | ESD Generator | HAEFELY | ONYX30 | 12/01/2015 | 12/01/2017 |
| X | Vertical coupling plane | SGS | -- | -- | -- |
| X | Insulated support (wood) | -- | -- | -- | -- |
| X | Reference ground plane (aluminium sheet metal 2x1 m) | SGS | -- | -- | -- |
| X | Weather Station | Testo 622 | TESTO | 29/02/2016 | 01/03/2017 |
| Supplementary information: | | | | | |

Test setup for Immunity to Electrostatic Discharges

Floor-standing equipment



The figure shows an example of test setup

**ESD Waveform Verification
(Optional)**

| | |
|--------------------------------|--------------------------------|
| Positive 6 kV Amplitude | Negative 6 kV Amplitude |
|--------------------------------|--------------------------------|

| Tabulated Results for Electrostatic Discharges | | | |
|--|--------------------------------|----------|--------|
| Nominal Voltage (V) | | | 230 V |
| Nominal Frequency (Hz) | | | 50 Hz |
| Direct discharges: Air and Contact | | | |
| Discharge location | Air discharge voltage (kV) | Polarity | Remark |
| 1 | 2, 4, 8 | +/- | 1 |
| 2 | 2, 4, 8 | +/- | 1 |
| 4 | 2, 4, 8 | +/- | 1 |
| 5 | 2, 4, 8 | +/- | 1 |
| 6 | 2, 4, 8 | +/- | 1 |
| 7 | 2, 4, 8 | +/- | 1 |
| 9 | 2, 4, 8 | +/- | 1 |
| 10 | 2, 4, 8 | +/- | 1 |
| 13 | 2, 4, 8 | +/- | 1 |
| 15 | 2, 4, 8 | +/- | 1 |
| 17 | 2, 4, 8 | +/- | 1 |
| 25 | 2, 4, 8 | +/- | 1 |
| 26 | 2, 4, 8 | +/- | 1 |
| 27 | 2, 4, 8 | +/- | 1 |
| 28 | 2, 4, 8 | +/- | 1 |
| 29 | 2, 4, 8 | +/- | 1 |
| 30 | 2, 4, 8 | +/- | 1 |
| 31 | 2, 4, 8 | +/- | 1 |
| 32 | 2, 4, 8 | +/- | 1 |
| 33 | 2, 4, 8 | +/- | 1 |
| Discharge location | Contact discharge voltage (kV) | Polarity | Remark |
| 3 | 2, 4, 6 | +/- | 1 |
| 8 | 2, 4, 6 | +/- | 1 |
| 11 | 2, 4, 6 | +/- | 1 |
| 12 | 2, 4, 6 | +/- | 1 |
| 14 | 2, 4, 6 | +/- | 1 |
| 16 | 2, 4, 6 | +/- | 1 |
| 18 | 2, 4, 6 | +/- | 1 |
| 19 | 2, 4, 6 | +/- | 1 |
| 20 | 2, 4, 6 | +/- | 1 |
| 21 | 2, 4, 6 | +/- | 1 |
| 22 | 2, 4, 6 | +/- | 1 |
| 23 | 2, 4, 6 | +/- | 1 |
| 24 | 2, 4, 6 | +/- | 1 |


| Indirect discharges | | | |
|---------------------|--------------------------------|----------|--------|
| Discharge location | Contact discharge voltage (kV) | Polarity | Remark |
| HCP – Front | 2, 4, 6 | +/- | 1 |
| HCP – Left | 2, 4, 6 | +/- | 1 |
| HCP – Right | 2, 4, 6 | +/- | 1 |
| HCP – Rear | 2, 4, 6 | +/- | 1 |
| VCP – Front | 2, 4, 6 | +/- | 1 |
| VCP – Left | 2, 4, 6 | +/- | 1 |
| VCP – Right | 2, 4, 6 | +/- | 1 |
| VCP – Rear | 2, 4, 6 | +/- | 1 |

Results Descriptions:

X - Not Performed nor required.

1 – Compliant - No observed response from EUT. Verifying leds of the movement handle and normal function.

Graphic representation for Electrostatic Discharges




1.13 Test Conditions and Results - Immunity to Radio Frequency Electromagnetic Fields

| | | | | | |
|--|-------------------------------------|--|---|--|----------|
| 61000-4-3 | | TEST: RF electromagnetic fields (IEC 61000-4-3: - use latest edition) | | Verdict | |
| <p><u>Method:</u> The test allows estimating of the radiated immunity of electrical and electronic equipment to electromagnetic disturbances coming from intended radio-frequency (RF) transmitters in the frequency range 80 MHz to 2500 MHz. The interference is applied on the enclosure of the equipment by using transmitting antennas.</p> | | | | | P |
| Laboratory Parameters: | | Required prior to the test | | During the test | |
| Ambient Temperature | | 15 to 35 °C | | 23 °C | |
| Relative Humidity | | 30 to 60 % | | 45 % | |
| Equipment mode | | Power interface mode | | 2 | |
| | | EUT configurations mode | | 2 | |
| | | Operation mode | | 1 | |
| Test specifications | | | | | |
| Calibration Requirements | | | Uniform field area (UFA) | 1.5 m x 1.5 m, 16 points with a minimum UFA size 0.5 m x 0.5 m | |
| | | | | 75 % of calibration points within specifications if UFA is larger than 0.5 m x 0.5 m. 100 % (all 4 points) in the specifications for 0.5 x 0.5 m UFA | |
| Frequency bandwidth | | | 80 MHz to 2500 MHz | | |
| Level | <input checked="" type="checkbox"/> | Non-Life Supporting Equipment | Amplitude modulation | 3 V/m | |
| | | | | 80 % / 1 kHz sine wave | |
| | | | Amplitude modulation | Controls, monitors or measures a physiological parameter, (80 % / 2 Hz) | |
| | | | | 10 V/m | |
| <input type="checkbox"/> | Life Supporting Equipment | Amplitude modulation | 80 % / 1 kHz sine wave | | |
| | | | Controls, monitors or measures a physiological parameter, (80 % / 2 Hz) | | |
| Frequency step | | | 1% or less of fundamental test frequency | | |
| Dwell time | <input type="checkbox"/> | 2 Hz Modulation | 3 sec minimum | | |
| | <input checked="" type="checkbox"/> | 1 kHz Modulation | 1 sec minimum | | |
| Supplementary information: | | | | | |

| Test Equipment Used | | | | | |
|---------------------|-----------------------------|---------------------|---------|--------------------------|--------------------------|
| Used | Description | Manufacturer | Model | Cal. Date | Cal. Due |
| X | Signal generator | PMM | 3030-1 | 29/12/2015 | 29/12/2016 |
| X | Electromagnetic field meter | WANDEL & GOLTERMANN | EMR-300 | 22/09/2015 30/09/2016 | 22/09/2016 30/09/2017 |
| X | RF Amplifier | FRANKONIA | FLG-30C | 06/03/2016 | 06/03/2017 |
| X | RF Amplifier | FRANKONIA | FLH-70B | 05/07/2016 | 05/07/2018 |

Supplementary information:




| Tabulated Results for RF Electromagnetic Field 80 MHz to 2500 MHz | | | | |
|---|-----------------|----------------------------|---------------------|--------|
| Nominal Voltage (V) | | | | 230 V |
| Nominal Frequency (Hz)..... | | | | 50 Hz |
| Side of the equipment under test | Frequency (MHz) | Antenna polarization (V/H) | Dwell Time (second) | Remark |
| Left | 80 – 250 | V | 1 | 1 |
| | 80 – 250 | H | 1 | 1 |
| | 250 – 1000 | V | 1 | 1 |
| | 250 – 1000 | H | 1 | 1 |
| | 1000 – 2500 | V | 1 | 1 |
| | 1000 – 2500 | H | 1 | 1 |
| Back | | | | X |
| Front | | | | X |
| Right | | | | X |
| Supplementary information: | | | | |
| Results Descriptions: | | | | |
| X - Not performed nor required | | | | |
| 1 – Compliant - No observed response from EUT. Verifying leds of the movement handle and normal function. | | | | |
| Note: Left side is considered the worst side | | | | |

1.14 Test Conditions and Results – Electrical Fast Transients

| | | | |
|---|---|-----------------------------------|----------------|
| 61000-4-4 | TEST: Fast Transients – (IEC61000-4-4: - use latest edition) | | Verdict |
| <p><u>Method:</u> Measurements were made on a ground plane that extends 1-meter minimum beyond all sides of the system under test. Mains power tests were conducted with the product connected to a Coupling/Decoupling Network (CDN). I/O lines were tested in a Capacitive Coupling Clamp. One of each unique interface was tested for a period of one (1) minute per polarity.</p> | | | P |
| Laboratory Parameters: | Required prior to the test | During the test | |
| Ambient Temperature | 10 to 40 °C | 24°C | |
| Relative Humidity | 10 to 90 % | 42 % | |
| Fully configured sample subject to the levels shown below. | Measurement Point | | |
| | Input a.c. Power Ports | | |
| | Signal Ports longer than 3 meters | | |
| Equipment mode | Power interface mode | 1 & 2 | |
| | EUT configurations mode | 1 & 2 | |
| | Operation mode | 1 & 2 | |
| Applied Level | | | |
| Application Point | (kV) | Repetition Frequency (kHz) | |
| Input a.c. Power Ports | ±2 | 5 | |
| Movement handle cable | ±1 | 5 | |
| Supplementary information: | | | |

| Test Equipment Used | | | | | |
|----------------------------------|--|---------------------|--------------|-------------------|-------------------|
| Used | Description | Manufacturer | Model | Cal. Date | Cal. Due |
| X | EFT Generator | EMC PARTNER | TRA-3000 | 10/08/2015 (*) | 10/08/2016 (*) |
| X | Insulated support (wood) | -- | -- | -- | -- |
| X | Reference ground plane (2 aluminium sheet metal 2x1 m) | SGS | -- | -- | -- |
| Supplementary information: | | | | | |
| (*) Test performed on 2016/07/13 | | | | | |

| Electrical Fast Transients Waveform Verification (Optional) | |
|--|--|
| | |
| | |



| Tabulated Results for Minimum Input Voltage | |
|---|-------------------------|
| Minimum Rated Voltage (V).....: | 110 |
| Nominal Rated Frequency (Hz) : | 60 |
| Point of application | Comments/Results |
| Mains | 1 |
| I/O signal ports | 1 |
| Supplementary information: Result description: X – Not performed 1 – Compliant – No observed response from EUT. Verifying leds of the movement handle and normal function. | |
| Tabulated Results for Maximum Input Voltage | |
| Maximum Rated Voltage (V).....: | 230 |
| Nominal Rated Frequency (Hz) : | 50 |
| Point of application | Comments/Results |
| Mains | 1 |
| I/O signal ports | 1 |
| Supplementary information: Result description: X - Not performed 1 – Compliant - No observed response from EUT. Verifying leds of the movement handle and normal function. | |

1.15 Test Conditions and Results – Surge Immunity

| | | | |
|---|---|--|------------------------|
| 61000-4-5 | TEST: Surge Immunity Test – (IEC61000-4-5: - use latest edition) | | Verdict |
| <p><u>Method:</u> Mains power tests were conducted with the product connected to a Coupling/ Decoupling Network (CDN). The test voltage was increased from the lowest indicated level up to the maximum level. Five (5) positive surges and five (5) negative surges were applied at each of phases of the a.c. waveform: 0°, 90°, 180° and 270°. Each surge was applied 60 seconds after the previous surge. Signal and Telecommunications ports were subject to five (5) positive and five (negative) surges applied through the appropriate Coupling/Decoupling Network (CDN).</p> | | | P |
| Laboratory Parameters: | | Required prior to the test | During the test |
| Ambient Temperature | | 10 to 40 °C | 24°C |
| Relative Humidity | | 10 to 90 % | 42% |
| Fully configured sample subject to the levels shown below. | | Measurement Point | |
| | | Input AC Power Ports | |
| Equipment mode | | Power interface mode | 1 & 2 |
| | | EUT configurations mode | 1 & 2 |
| | | Operation mode | 1 & 2 |
| Applied Level | | | |
| Application Point | [kV] | Required Surge Waveform | |
| Input Power Ports | 0.5 and 1.0 (Line to Line) | Combination Wave (2µs x 50µs Voltage, 8µs x 20µs Current) | |
| | 0.5, 1.0 and 2.0 (Line to Earth) | | |
| ME EQUIPMENT and ME SYSTEMS that do not have a surge protection device in the primary power circuit may be tested only at 2 kV line(s) to earth and 1 kV line(s) to line(s). | | | |
| Supplementary information: | | | |

| Test Equipment Used | | | | | |
|----------------------------------|---|---------------------|--------------|-------------------|-------------------|
| Used | Description | Manufacturer | Model | Cal. Date | Cal. Due |
| X | SURGE Generator | EMC PARTNER | TRA-3000 | 10/08/2015 (*) | 10/08/2016 (*) |
| X | Insulated support (wood) | -- | -- | -- | -- |
| X | Reference ground plane (aluminium sheets metal 2x1 m) | SGS | -- | -- | -- |
| Supplementary information: | | | | | |
| (*) Test performed on 2016/07/13 | | | | | |

| |
|---|
| Surge Waveform Verification (Optional) |
| |

| |
|--|
| Test setup for Surge Immunity |
| Test setup similar to Electrical Fast Transients for supply line coupling |

| Tabulated Results for Surges for Minimum Input Voltage | | | |
|---|--------------|-----------------|-------------------------|
| Minimum Rated Voltage (V) | | | 110 |
| Nominal Rated Frequency (Hz) | | | 60 |
| Mode of Application – Mains | Level | Polarity | Comments/Results |
| Line 1 to Line 2 (Differential mode) | 0.5kV | Positive | X |
| | | Negative | X |
| | 1.0kV | Positive | 1 |
| | | Negative | 1 |
| Line 1 to Earth (Common mode) | 0.5kV | Positive | X |
| | | Negative | X |
| | 1.0kV | Positive | X |
| | | Negative | X |
| | 2.0kV | Positive | 1 |
| | | Negative | 1 |
| Line 2 to Earth (Common mode) | 0.5kV | Positive | X |
| | | Negative | X |
| | 1.0kV | Positive | X |
| | | Negative | X |
| | 2.0kV | Positive | 1 |
| | | Negative | 1 |

Supplementary information:
 Result description:
 X - Not performed
 1 – Compliant - No observed response from EUT. Verifying leds of the movement handle and normal function.


| Tabulated Results for Surges for Maximum Input Voltage | | | |
|---|--------------|-----------------|-----------------|
| Maximum Rated Voltage (V) ... | | | 230 |
| Nominal Rated Frequency (Hz) | | | 50 |
| Mode of Application - Mains | Level | Polarity | Comments |
| Line 1 to Line 2 (Differential mode) | 0.5kV | Positive | X |
| | | Negative | X |
| | 1.0kV | Positive | 1 |
| | | Negative | 1 |
| Line 1 to Earth (Common mode) | 0.5kV | Positive | X |
| | | Negative | X |
| | 1.0kV | Positive | X |
| | | Negative | X |
| | 2.0kV | Positive | 1 |
| | | Negative | 1 |
| Line 2 to Earth (Common mode) | 0.5kV | Positive | X |
| | | Negative | X |
| | 1.0kV | Positive | X |
| | | Negative | X |
| | 2.0kV | Positive | 1 |
| | | Negative | 1 |

Supplementary information:
 Result description:
 X - Not performed
 1 – Compliant - No observed response from EUT. Verifying leds of the movement handle and normal function.

1.16 Test Conditions and Results – Conducted Disturbances Immunity

| | | | | | |
|---|--|---|-------------------|--|----------|
| 61000-4-6 | | TEST: RF Continuous Conducted – (IEC61000-4-6: 2003 + A1:2004 + A2:2006) | | Verdict | |
| <p>Method: Measurements were made on a ground plane that extends 0.5-meter minimum beyond all sides of the system under test. The EUT was located 10cm above the reference ground plane and any associated I/O cables attached to the EUT were located between 30mm and 50mm above the ground plane. The indicated field was pre-calibrated prior to placement of the system under test.</p> | | | | | P |
| Laboratory Parameters: | | Required prior to the test | | During the test | |
| Ambient Temperature | | 10 to 40 °C | | 24°C | |
| Relative Humidity | | 10 to 90 % | | 45% | |
| Equipment mode | | Power interface mode | | 2 | |
| | | EUT configurations mode | | 2 | |
| | | Operation mode | | 1 & 2 | |
| Test Specifications: | | Frequency range | | Measurement Point | |
| Fully configured sample scanned over the following frequency range | | 150kHz to 80MHz | | Input a.c. Power Ports Signal Ports | |
| Level | <input checked="" type="checkbox"/> Non-Life Supporting Equipment | 3 V RMS | | | |
| | | Amplitude modulation | 80 % / 1 kHz sine | | |
| | Controls, monitors or measures a physiological parameter (80 % / 2 Hz) | | | | |
| | <input type="checkbox"/> Life Supporting Equipment | 3 V RMS outside the ISM band, 10 V RMS in the ISM band | | | |
| Amplitude modulation | | 80 % / 1 kHz sine | | | |
| | Controls, monitors or measures a physiological parameter (80 % / 2 Hz) | | | | |
| Frequency step | | 1% or less of fundamental test frequency | | | |
| Dwell time | <input type="checkbox"/> 2 Hz Modulation | 3 sec minimum | | | |
| | <input checked="" type="checkbox"/> 1 kHz Modulation | 1 sec minimum | | | |
| Supplementary information: | | | | | |

| Test Equipment Used | | | | | |
|----------------------------|------------------------------|---------------------|---------------|--------------------------|--------------------------|
| Used | Description | Manufacturer | Model | Cal. Date | Cal. Due |
| X | Signal generator | PMM | 3030-1 | 29/12/2015 | 29/12/2016 |
| X | RF Amplifier | FRANKONIA | FLL-25 | 28/08/2014 02/09/2016 | 28/08/2016 02/09/2018 |
| X | Supply line coupling network | FCC | FCC-801-M3-25 | 14/11/2014 | 14/11/2016 |
| Supplementary information: | | | | | |




| Tabulated Results for Conducted Disturbances | | |
|---|------------------|---------------------|
| Nominal Rated Voltage (V) | | 230 |
| Nominal Rated Frequency (Hz) | | 50 |
| Point of Application | Comments/Results | Dwell Time (second) |
| Mains | 1 | 1 |
| I/O signal ports | 1 | 1 |
| Supplementary information: Result description: X - Not performed 1 – Compliant - No observed response from EUT. Verifying leds of the movement handle and normal function. | | |

1.17 Test Conditions and Results – Voltage Dips, Interruptions, and Variations

| | | | |
|--|---|-----------------------------------|-----------------------------|
| 61000-4-11 | TEST: Voltage Dips and Interruptions – (IEC61000-4-11: - use latest edition) | | Verdict |
| <p><u>Method:</u> The product was subjected to voltage dips and interruptions. Testing was performed with the product connected directly to a generator capable of simulating the voltage drops and interrupts as described.</p> | | | P |
| Laboratory Parameters: | | Required prior to the test | During the test |
| Ambient Temperature | | 10 to 40 °C | 23°C |
| Relative Humidity | | 10 to 90 % | 41% |
| Fully configured subjected to the levels indicated below. | | Measurement Point | |
| | | Input A.C. Power Ports | |
| Equipment mode | Power interface mode | | 2 & 3 |
| | EUT configurations mode | | 2 & 3 |
| | Operation mode | | 1 & 2 |
| Applied Levels | | | |
| Voltage Dips % U_T | | Period (Cycles) | Sync Angle [degrees] |
| 30 | | 25 | 0 |
| 60 | | 5 | 0 |
| >95 | | 0.5 | 0, 180 |
| Voltage Interruption % U_T | | Seconds | Sync Angle [degrees] |
| >95 | | 5 | 0 |
| 0 degrees is the crossover point of the voltage waveform. | | | |
| Supplementary information: | | | |

| Test Equipment Used | | | | | |
|----------------------------|--------------------|---------------------|--------------|------------------|-----------------|
| Used | Description | Manufacturer | Model | Cal. Date | Cal. Due |
| X | AC Power supply | PACIFIC | 360-AMX | 13/07/2015 | 13/07/2017 |
| Supplementary information: | | | | | |



| Voltage Dips and Interruption Verifications (Optional) | |
|---|---------------------------------|
| 30% Dip | 60% Dip |
| | |
| >95% Interruption | |
| | Intentionally Left Blank |

| Power Interface Mode # | EUT Configurations Mode # | EUT Operation Mode # |
|---------------------------------|----------------------------------|-----------------------------|
| 1 | 2 | 1 & 2 |
| 2 | 3 | 1 & 2 |
| Supplementary information: None | | |

| Tabulated Results for Voltage Dips and Interruptions | | | |
|---|--------------------------|------------------------|-------------------------|
| Minimum Rated Voltage (V)..... | | | 110 |
| Maximum Rated Frequency (Hz) | | | 50 |
| Point of application | Voltage reduction | Period (Cycles) | Comments/Results |
| Mains | 30 | 25 | 1 |
| Mains | 60 | 5 | 1 |
| Mains | >95 | 0.5 | 1 |
| Point of application | Voltage reduction | Seconds | Comments/Results |
| Mains | >95 | 5 | 1 |

Supplementary information:
 Result description:
 1 – Compliant – No Observed/perceived response from EUT. Verifying leds of the movement handle and normal function.

| Tabulated Results for Voltage Dips and Interruptions | | | |
|---|--------------------------|------------------------|-------------------------|
| Maximum Rated Voltage (V).... | | | 230 |
| Minimum Rated Frequency (Hz) | | | 50 |
| Point of application | Voltage reduction | Period (Cycles) | Comments/Results |
| Mains | 30 | 25 | 1 |
| Mains | 60 | 5 | 1 |
| Mains | >95 | 0.5 | 1 |
| Point of application | Voltage reduction | Seconds | Comments/Results |
| Mains | >95 | 5 | 1 |

Supplementary information:
 Result description:
 1 – Compliant – No Observed/perceived response from EUT. Verifying leds of the movement handle and normal function.


1.18 Test Conditions and Results – Power- Frequency Magnetic Fields

| | | | |
|---|---|-----------------------------------|------------------------|
| 61000-4-8 | TEST: Power-frequency magnetic field – (IEC61000-4-8: - use latest edition) | | Verdict |
| <p>Method: Measurements were made on a ground plane that extends 1-meter minimum beyond sides of the system under test. Table top EUT is located 80cm above the reference ground plane and floor-standing EUT is located 10cm above the reference ground plane. The indicated field was pre-calibrated prior to placement of the EUT under test.</p> | | | P |
| Laboratory Parameters: | | Required prior to the test | During the test |
| Ambient Temperature | | 10 to 40 °C | 23°C |
| Relative Humidity | | 10 to 90 % | 41% |
| Equipment mode | | Power interface mode | 2 & 4 |
| | | EUT configurations mode | 2 & 4 |
| | | Operation mode | 1 & 2 |
| Fully configured sample tested at the power line frequency (See Note 1) | | Frequency | Application Point |
| | | 50Hz and 60 Hz ¹ | Enclosure |
| Frequency (Hz) | | Test Level (A/m) | |
| 50 | | 3 | |
| 60 | | 3 | |
| Supplementary information: | | | |

| Test Equipment Used | | | | | |
|----------------------------|-----------------------------|--------------|---------|------------|------------|
| Used | Description | Manufacturer | Model | Cal. Date | Cal. Due |
| X | AC Power supply | PACIFIC | 360-AMX | 13/07/2015 | 13/07/2017 |
| X | Electromagnetic field meter | HOLADAY | HI-3604 | 14/07/2016 | 14/07/2018 |
| X | Square coil (1x1 m) | SGS | -- | 14/07/2016 | 14/07/2018 |
| Supplementary information: | | | | | |

Test setup for Power- Frequency Magnetic Fields

Floor-standing equipment



- GRP: Ground plane
- A: Safety earth
- S: Insulating support
- EUT: Equipment under test
- Ic: Induction coil
- E: Earth terminal
- C1: Power supply circuit
- C2: Signal circuit
- L: Communication line
- B: To power supply source
- D: To signal source, simulator
- G: To the test generator

The figure shows an example of test setup

Tabulated Results for Power Frequency Magnetic Field

| Nominal Rated Voltage (V) | | 230 |
|--|----------------|--------------|
| Point of application | Results | |
| | 50 Hz | 60 Hz |
| X-Axis | 1 | 1 |
| Y-Axis | 1 | 1 |
| Z-Axis | 1 | 1 |

Supplementary information:

Result description:

X - Not performed

1 – Compliant - No observed response from EUT. Verifying leds of the movement handle and normal function.