



General

Calculation algorithm used
Maintenance factor

High indirect fraction
0.80

Total lamp luminous flux
Luminaire luminous flux
Total power
Total power per area (504.74 m²)

321250 lm
300912 lm
3357.6 W
6.65 W/m² (2.02 W/m²/100lx)

Evaluation area

\bar{E}_m 330 lx
 E_{min} 4 lx
 $E_{min}/\bar{E}_m (U_o)$ 0.01
 $E_{min}/E_{max} (U_d)$ 0.00
 E_z/E_h
Position 0.50 m

142 lx
3 lx
0.02
0.38
0.95 m