



1. DESCRIPTION


The DA-GEN is an innovative water treatment system and additionally an intelligent pool controller. The DA-GEN combines Hydrolysis with Electrolysis with a low mineral content.

The Hydrolysis produces free radicals and other oxygen compounds like ozone, peroxide and persulfate. All these oxidants destroy organic substances and pathogens in the water. Free radicals are the strongest oxidants we know. They oxidise and decompose in a few seconds. To guarantee a safe residual disinfection the DA-GEN produces a very small amount of chlorine. In combination with Dryden DAISY® we need a very low mineral content of 1 to 2 kg MgCl₂ or 0.75 to 1.5 kg NaCl per m³.

The DA-GEN also controls all your pool equipment centrally. Thanks to WiFi you can check and control your pool system 24/7.



Control panel




- 1 Connection cell
- 2 Gas detector connection
- 3 Main 230V connection
- 4 ON/OFF switch



- 5 4 Amp fuse for panel and cell
- 6 4 Amp fuse relays

Cell



- 1 Cell
- 2 Gas detector connector
- 3 Cell connector
- 4 Cell housing
- 5 Gas detector (internal)¹

¹Except DA-GEN 150

2. MAIN SCREEN

Heating ON/OFF

Status of the auxiliary relays

Current time

Production intensity
in % (normally 40-100%)

Atit. reikl 1.3 ir 1.4
Automatic measurements: pH/redoX/
free chlorine/conductivity (according to options)

Status of filtration relay
(see chapter 12- Filtration)

man Manual
aut Automatic

Water temperature

Cover If the cover is open the filtration speed is "medium" (if with frequency controlled pump)

Pol 1 Polarity 1 / **Pol 2** Polarity 2

--- Waiting time

Flow Filtration stopped due to lack of water flow

Low Lack of conductivity or salt / low water temperature / scale on cell / exhausted cell (check working hours)

7.4 pH Setpoint

ON/OFF Function of pH dosing pump

AL3 Maximum dosing time exceeded (⊖ to reset the alarm)

7.0 Setpoint pH minimum (if using pH-Minus and pH-Plus)

ON/OFF Additional chlorine pump (optional)

FL 1 Flow alarm (Paddle/Gas)

700 Minimum Redox Setpoint

AL3 Maximum dosing time exceeded (⊖ to reset the alarm)

0.30 Free Chlorine Minimum Setpoint

FL 1 Flow alarm (Paddle/Gas) / **FL 2** Flow alarm rotameter Cl₂

AL3 Maximum dosing time exceeded (⊖ to reset the alarm)


TANK Low level pH-Minus bottle

Communication display – mother board

Lights
man Manual / **aut** Automatic

- +** **PLUS** key
Modify value/selection
Shortcut Backwash
(press 3s)
- **MINUS** key
Modify value/selection
Shortcut Light
(press 3s)
- OK** key
Select/confirm
- ▲** **UP** key
Navigation up
- ▼** **DOWN** key
Navigation down
- ↶** **RETURN/ESCAPE** key

3. SYSTEM INSTALLATION



Electrical consumption

Use of a 13 Amp time delay circuit breaker is recommended for private devices and a 16 A breaker for public devices. In case of sharing the power supply with other devices please consult a technician in order to dimension a correct installation.

Atit. reikl 1.5


Product	Maximum consumption	Product	Maximum consumption
DA-GEN 24	90 W	DA-GEN 240	680 W
DA-GEN 45	125 W	DA-GEN 360	1000 W
DA-GEN 90	180 W	DA-GEN 500	1020 W
DA-GEN 150	175 W	DA-GEN 750	2880 W
Private		Public	

- A** External pump controller*
- B** Filter with AFM®
- C** Filter pump
- 1** Control Panel
- 2** Free chlorine cell with rotameter
- 3** Cell (always in vertical position if installed without paddle flow switch **6**)
- 4** pH probe
- 5** Redox probe and/or conductivity probe
- 6** Paddle flow switch and temperature module
- 7** APF® dosing pump
- 8** pH dosing pump
- 9** pH injection
- 10** Prefilter
- 11** Wifi module
- 12** APF® (not included)
- 13** pH-Minus (not included)
- 14** If Outdoor pool: ACO® (not included)
- 15** Besgo valve (not included)


Atit. reikl 1.6

Atit. reik. 1.1

* Filtration control by external timer



* Filtration control by internal timer




At. r. 1.7

Ati.r 1.4

Atit. reikl. 1.3

4. ELECTRICAL CONNECTIONS

CONNECT ALL THE SENSORS CAREFULLY, A BAD CONNECTION MAY CAUSE IRREPARABLE DAMAGE TO THE DEVICE



1 *IF connecting 2 displays on the device, remember not to connect the second display in this communication channel. Use the "ext. Display" socket instead.

5. INITIAL WATER ADJUSTMENTS

Water adjustments

- 1 Adjust the alkalinity between 100 and 200 ppm.
- 2 Adjust the pH to 7.4.
- 3 Adjust the chlorine between 0.1 and 0.5 ppm.

Attention: Do not calibrate free chlorine with a chlorine level of less than 0.3 ppm free chlorine!

Adding activator/salt to the water

- 1 We recommend to add 1 to 2 kg magnesium chloride ($MgCl_2$) or 0.75 - 1.5 kg of normal salt (NaCl) per m^3 of water. The TDS should be at around 1200. It is recommended to mix them, for example in a ratio 1:3 ($MgCl_2$:NaCl).
- 2 Add the magnesium chloride or salt directly to your swimming pool and let the system run.


In outdoor pools it is necessary to use ACO®.

6. SYSTEM SETTINGS




OK

↩




OK

↩




OK

↩



OK


↩



6.3 Language


6.5 Date and Time

6.7 Display brightness




OK

↩



OK

↩




6.9 Sound

6.11 Password: Protect the user's menu by activating a password. To enter your password press a combination of 5 keys and the system will memorise them. If you forget the password, there is a "master password". Ask your installer/provider.




OK

↩



OK

↩



OK

↩



6.12 Hydrolyse-Cell working hours

6.14 System info: Information about the software versions and the ID node

7. PADDLE FLOW SWITCH

Paddle flow switch. Stops the hydrolysis and the dosing pumps if there is no water flow.



Paddle Flow switch **FL1** 2 & 3

Connect as shown in the image and contact your installer for activation.


8. SUCTION LANCE (pH BOTTLE)



pH-Minus bottle level **TANK** 4 & 5

Connect the suction lance. The installer/provider should be contacted to activate the sensor.

9. HYDROLYSIS



9.1 Hydrolysis: Programming of hydrolysis functions



9.2 Level: Hydrolysis - Desired disinfection production (Always 100%).




9.3 Mode: If the device has Free Chlorine and redox probes, choose the parameter that controls the cell's chlorine generation.

10. MEASUREMENTS




OK

↑



OK

↑




10.1 Measurements: Adjustment of setpoints and measuring probes.
10.2 Setpoints for each measurement.
10.3 Setpoints:
pH: 7.0-7.4; **redox:** 600 - 800 mV; **free chlorine:** 0.1- 0.5 ppm; **conductivity:** ~ 2000 µS

10.1 pH Calibration

pH module

Atit. reikl. 1.3



OK

↑




OK

↑



10.11 Calibration of pH probe: Recommended at least every 2-3 months during the usage season. Calibrate it always first with the Buffer (2pt).
10.12 Calibration with buffers (buffer pH7 / pH10 / neutral): Follow the instructions that appear on the display.



OK

↑




10.14 Manual calibration: Allows manual adjustment of the probes – only recommended to correct small deviations in the readings.
10.15 Without removing the probe from the water, use the **plus/minus** keys to adjust the reading so it matches your reference value (photometer or other measurement).

10.2 Temperature calibration


Temperature module

Temperature probe
 1 red
 2 yellow
 3 black



OK

↑



10.22 Temperature calibration: To set the difference between the measured value of the probe and the actual temperature, use the **plus/minus** and **up/down** keys. Set to the actual temperature of the probe and press **OK**.

10.3 Free Chlorine calibration

Atit. reikl. 1.4

Free Chlorine control




Free Chlorine probe
 3 red 4 black



Chlorine probe detector
FL2 (rotameter)
 3 black
 5 brown
 6 blue

If using a Variable Speed Pump, calibrate the probe using the lowest filtration speed.



OK

↑



OK

↑



Attention: Do not calibrate if the free chlorine level is below 0.3 ppm!

10.31 Calibration of the Free Chlorine probe: Recommended at least every 2 to 3 months
10.32 Calibration with buffer (photometer DPD1): Follow the instructions in 6 steps that appear in the display.
10.33 Step 1 of 6 - Calibrate Cl at 0 ppm (offset): Close the water flow through the probe and wait for 5 to 60 min until the reading is close to 0. Press **OK**



10.34 Step 3 of 6 - Calibrate Cl: Set the water flow to the correct rate of 80-100 litres/hour. Wait for 5 to 20 min until there is a stable ppm reading. Press **OK**.
10.35 Step 5 of 6 - Establish the real ppm values with the **plus/minus** keys according to your DPD1 (free chlorine) value
10.36 Step 6 of 6 - If this screen is not shown repeat the calibration process.



OK

↑



4.38 Manual calibration: Open the water flow and set the flowmeter (rotameter) to the correct flowrate (50-100l/h). Wait until the current level is stable. Set the chlorine level with the **plus/minus** keys, manually (use a manual DPD1 test kit). Press **OK** when value is correct.


10.4 Redox Calibration

The redox value shows the oxidation/reduction potential and is used to determine the sterility of the water. Adjusting the ideal redox level (setpoint) is the last step in the system start up sequence.

Redox control



Attention: Use only gold redox probes!



10.41 Calibration of the redox probe: Recommended at least every 2 to 3 months.

10.42 Calibration with buffer (buffer solution 465 mV): Follow the instructions that appear on the display



10.44 Manual calibration: Not recommended!

10.5 Conductivity calibration




Optional Conductivity probe

Metering and control of the conductivity of the water in μS





Conductivity probe
 1 yellow
 2 transparent

1000 TDS \approx 1800 μS




10.51 Calibration of the Conductivity probe: Recommended every month during usage season.

10.52 Calibration with buffer (buffer solution 1413 μS / 12880 μS / neutro): Follow the instructions in 7 steps that appear in the display (screen 4.24 corresponds to step 1).





10.54 Manual calibration: Not recommended!

11. VARIABLE SPEED PUMP



Variable Speed Pump

1 slow 2 medium 3 fast 4 common



11.1 Variable Speed Pump: To install a Variable Speed Pump contact your installer.

11.2 - 11.5 After connecting the pump, each filtration period can be assigned a different speed
 F: fast, M: medium and S: slow.

See chapter 12 - Filtration



11.5 Filter cleaning: To backwash the filter with a Variable Speed Pump use the fastest speed.


See chapter 13 - automatic backwash

Please see the wiring schemata in the appendix!

12. FILTRATION



12.1 Manual mode

Only with an external pump controller unit



Setup and connection of a Variable Speed Pump, see section 11 - Variable Speed Pump

FILTER PUMP
Filtration control 7 & 8



12.11 Filtration:

Configuration control of the filter pump. To set, select Filtration and confirm by pressing **OK**. The mode selection is done in Mode line with the **plus/minus** keys.


12.12 Manual:

Manually turns **ON/OFF** the filtration process. No timing or additional functions. The State (Status) line indicates whether the filtration pump is **ON**.

Filter Cleaning: See chapter 13

12.2 Automatic mode

Without an external pump controller unit



12.21 Automatic

In this mode the filtration is controlled by up to 3 timers.

We hardly recommend to run your system in a 24/7 mode with a variable speed pump.


For example: During the night time (6:00 until 24:00 & 0:00 until 10:00) in low speed, during day time (10:00 until 6:00) in medium speed.

To set the **ON/OFF** times select with the **up/down** keys in the timer line you want to change (1-3).

The **plus/minus** keys open the selected start time field. Set the time with **plus/minus** keys. Scroll with the **up** key to the minute field and set it up with **plus/minus** keys. To confirm press **OK** and to cancel press **return/escape**.

Backwash: See chapter 13


13. AUTOMATIC BACKWASH



13.1 Backwash Mode with Besgo Valve: The DA-GEN is configured for automatic backwash with Besgo. Use AUX 2!

- Mode: Choose Auto
- Start: Choose starting time
- Interval: Set backwash time in seconds (Recommendation: min. 240 seconds with AFM®, min. 300 seconds with Sand)
- Freq.: Choose frequency (at least weekly)
- Shortcut: Enable/Disable Shortcut for manual backwash

14. LIGHTING




LIGHT
Lighting control 9 & 10



14.1 Lighting


14.2 Manual Mode (ON/OFF). You can activate the light also by pressing the shortcut. You can set a timer, after that the light will go out.

14.3 Automatic Mode: Switches lights according to timer settings. Additional you can switch the lights on by pressing the Shortcut button





14.5 LED spotlight: In case of installation of RGB LED lights in the pool, you can change the color of the lights in the pool. Select the length of time in seconds in Pulse length and then press Next Program option to apply the pulse. Refer to your LED spotlight manual to set its different colors.

15. WIFI SETTINGS



Connection WiFi module

- 1 red 2 yellow
- 3 green 4 black



15.1 Internet: Once the WiFi module is connected, restart the unit. The internet option will appear in the settings menu.

15.2 WiFi: Select WiFi to scan the available networks accessible to the module. The search will be done automatically.

15.3 Select the desired network accessible to the WiFi module.

15.4 Enter the password in the pop-up keyboard. Scroll up and down with the **up/down** keys and left to right with the **plus/minus** keys. To select a letter press **OK**.

15.5 Enter AP: If you do not find your Network in the automatic mode, then you can enter the network name manually. Check first if the network works on other devices.

15.6 Configuration: For a more detailed configuration enter this menu or contact your installer.



15.8 Status: Check the status of your connection.

15.9 Test connection: Check if your connection has been successfully established.

Once the WiFi module is connected to the network with both lights **ON**, enter in www.DA-GEN.com. Access the Register option and enter all the data requested.



15.10 - 15.13 The system node ID that you will need for the registration progress is located under System settings > System info > Power module

Upon completion of the process, you will have total control of your pool, will be able change parameters such as setpoints, filtration hours and turn ON/OFF any auxiliary relays.



17. COVER


Cover 1 & 6





17.1 Cover: If the DA-GEN is runned with a frequency controlled pump and if it is connected to the pool cover, the filtration speed will automatically go to «medium» when the cover is opened. (Please check the filtration speed in Chapter E). Set the Reduction value to 0%!

How to install: If the cover is open, the contact has to be closed and vice versa

18. AUXILIARY RELAYS



The auxiliary relays are configured by default. If you want to reassign the relays for other accessories, you must access the "Service Menu". Contact your authorised installer.



18.2 It is possible to control up to 4 extra auxiliary relays (water attractions, dosing pumps, etc). In default setting you will only see two available relays: APF® and ACO®: (AUX 1 and 3). AUX 2 is reserved for the Besgo Valve and therefore not shown here. If you do not have a heating, you can deactivate it (Chapter C & D in the service manual) and you will get an additional free relay (AUX4).

18.3 Manual mode (ON/OFF).

18.4 Automatic mode: ON/OFF according to a timer that adjusts the start and end of the program. The timers can be configured with a frequency.

18.5 Timer mode: Working time is programmed in minutes. Each time the Shortcut on the front panel is pressed, it will start up and run for the programmed time. This function is recommended for timing of air pumps of spas.

18.7 Rename relays: It is possible to rename each auxiliary relay to suit the use you want to assign. By pressing the plus/minus keys, a pop-up keyboard will appear. Scroll up and down with the up/down keys and left to right with the plus/minus keys. To select a letter press the OK.

19. MAINTENANCE

Monthly checks

SALT CONCENTRATION:

~1200 ppm TDS/mS
~2000 µS

HYDROLYSIS CELL: Visual inspection to detect incrustations.

Cleaning the Cell

If necessary, carry out a monthly visual inspection. To clean the cell:

- 1 Stop the system and close the valves
- 2 Place the cell for no more than 10 minutes in 3% hydrochloric acid or put it for 2 to 4 hours in normal vinegar.
- 3 Once the incrustations have softened remove with a hose to complete cleaning the cell.

DO NOT USE METALLIC OR SHARP OBJECTS TO REMOVE INCRUSTATIONS. Scratching the edges or surface of the cell will make it vulnerable to chemicals, deteriorate the cell and invalidate the guarantee.

General maintenance

- 1 The pool must be vacuumed as usual and the skimmers emptied whenever necessary.
- 2 **FILTER BACKWASHING:** At least once every week for 4 to 5 minutes.
VERY IMPORTANT: Make sure the cell is off while cleaning the filter. If the system controls the filtration pump, use the option "backwash" of the programmed filtration mode. See chapter 13 - automatic backwash
- 3 Check regularly the level of your pH and APF® bottle to prevent the dosing pump from running dry.
- 4 pH / Redox / Conductivity – probes: The probes must be cleaned and recalibrated every 2 to 3 months. To clean the probe insert in electrode cleaner. After each clean the probes must be re-calibrated.

Attention: the probes should never dry out and must be kept wet if stored (when emptying the pool for winterising, make sure to store the probe head in water).

20. TROUBLESHOOTING

Blank display

- Check if ON/OFF switch is illuminated.
- Check the connection wire between display and motherboard.
- Check the 3.15 A fuse of the device – it could have tripped due to overload.
- Check the power supply – 230V/50Hz.
- If the problem persists contact TECHNICAL SERVICE

Hydrolysis does not reach the setpoint value

- Attention: At 1200 TDS, 50 - 80% and the warning "LOW" is normal
- Low water temperature.
- Check the salt concentration (TDS) in water.
- Check the cell status (it may be incrustated or calcified).
- Clean the cell according to the instructions in section 19.
- Check that the cell is not worn out (remember that the cell is guaranteed for 5,000 hours, approx. 2-3 years of summer usage).

Free chlorine level doesn't reach the setpoint

- Increase the filtration hours to 24 hours
- Increase the hydrolysis level (to 100%).
- Increase the salt concentration (TDS) in the water. Setpoint app. 1200 ppm.
- In an outdoor pool: Add ACO® to the water.
- Check if the reagents in test kit are in date.
- Check if the temperature or number of users has risen.
- If you want a higher chlorine level you have to increase the salt concentration. Attention: Higher risk of corrosion!

Hydrolysis display shows FLOW

- Check gas and paddle flow detector cable.
- Clean for incrustations of the paddle flow detector at the top of the cell housing.
- Check to see if system is free of air (gas detector must always be submerged).

Polarity 1 reaches maximum intensity, but polarity 2 (auto clean) does not reach maximum intensity

- If the salt concentration is correct (1 - 2 kg/m³ MgCl₂ or 0.75 - 1.5 kg/m³ NaCl): The cell is reaching its end of life. As of this moment check the intensity every 15-20 days.
- When polarity 2 does not reach intensity of Polarity 1, we recommend substituting the cell for a new one if it happens during the summer period. If it happens during winter, change the cell before the next summer period.

Dosing pump is not working properly

- Check fuse on the right side of the dosing pump
- Check (and change) the dosing speed
- Check electrical connections
- Check tubes and fittings for leaks
- Check if injection valve is blocked
- Check if suction lance/suction weight is blocked
- Check if error message «TANK» appears. If yes replace bottle, if not check the polarity of the suction lance or replace the suction lance

Excess of chlorine in the water

- Lower hydrolysis cell intensity.
- If your system includes automatic Redox control, check the Redox setpoint value. Reduce it by 50 to 100 mV.
- If your system includes free chlorine measurement, adjust the setpoint value.
- Check redox probe and calibrate it if necessary.
- Check the free chlorine probe and calibrate it.

Cell incrustated in less than 1 month

- Very hard waters with a high pH and total alkalinity: balance water adjusting pH and total alkalinity.
- Check to ensure that the system automatically changes polarity approximately every 300 minutes.
- Consult with our technical service to consider accelerating the polarity change (auto-cleaning) . WARNING: Accelerating the polarity change decreases the cell life (5,000 hours) proportionally. Don't go below 200 minutes!

Alarm AL3 and pH dosing pump stopped

- The maximum dosing time (standard 999 min.) is accomplished and the pH-Minus dosing pump stops in order to avoid the acidification of the water.
- To delete the message and to restart the metering press ESC (⊙). Do the following verifications in order to preclude errors on the device: Verify if the pH probe reading is correct (if not, calibrate the probe or substitute it with a new one); Verify if the acid/base reservoir is full and if the dosing pump is working correctly; Verify the variable speed of the dosing pump.

Rust on metallic components in the pool

- Metallic elements lack standardised earth connection. Contact an electrician to solve the problem.
- Rusted components are not stainless steel (minimum 316/V4A/1.4571).
- The salt concentration (TDS) is too high.
- Attention Stainless Steel parts must be cleaned regularly

21. IMPORTANT NOTES



WARNING

Keep chemical levels in pool as instructed in this manual.

CLEANING FILTER

Very Important: Make sure the cell is off while cleaning/backwashing the filter. If the system controls the filtration pump, use the option "filter cleaning" of the programmed filtration mode. See section 5 – Filtration / Filter Cleaning of the General Installation Guide.

VERY IMPORTANT

Remember that the system needs some time to adapt to your pool (up to 14 days)!

SECURITY


To avoid accidents, children should not handle this product unless supervised by an adult. Children should be supervised at all times when in or near a spa, pool or jacuzzi.

HANDLING AND DOSING DANGEROUS CHEMICALS


Chemicals should be handled with extreme caution. When preparing acid, always add acid to water, never add water to acid, because very dangerous gases may be produced.

A) ELECTRICAL CONNECTIONS

 CONNECT ALL THE SENSORS CAREFULLY, A BAD CONNECTION MAY CAUSE IRREPARABLE DAMAGE TO THE DEVICE **Atit_reikl 1.11**




B) SERVICE MENU



Accessing the Service Menu:
B.1: Main screen (according to model)
B.2: Select System Settings
B.3: Select Service Menu
B.4: Enter password

C) RELAY CONFIGURATION




* Recommended relay settings.

Note: "NO" will deactivate the predefined parameters and leave the relay available.

D) SERVICE SETTINGS



D.2 Parameters related to external devices




Service settings	Range	Dimension	Standard factory value	Description
3 Flow mode select RW Val: 1 0001	0...4		1 (Redox) 3(Free chlorine)	0 - FL1 Lack of water flow - It turns off only the cell. 1 - FL1 Lack of water flow - It turns off everything (cells, pumps,...) 2 - FL2 Lack of water flow - It turns off only the cell. 3 - FL2 Lack of water flow - It turns off everything (cells, pumps,...) 4 - FL1 & FL2 If both detected no water flow, it turns off everything (cells, pumps,...)
4 Hydrolysis mode RW Val: 1 0001	0...2		1	Configures stops/starts of the hydrolysis cell and auxiliary disinfection pump on Relay AUX 2 according to redoX reading. 0 - Without redoX/CL ₂ (hydrolysis cell is always ON) - Auxiliary disinfection pump is controlled by redoX/free chlorine CL ₂ . 1 - With redoX/CL ₂ (redoX/free Cl set point stops/starts hydrolysis cell) - Auxiliary disinfection dosing pump is activated if redoX falls more than 2% lower than set point. 2 - With redoX/CL ₂ (redoX set point stops/starts hydrolysis cell) - Auxiliary free chlorine dosing pumps are controlled via time delays of parameters 8 and 9.
5 Hidro pol 1 time RW Val: 300 012C	0...999	Minutes	300	Polarity 1 of hydrolysis cell. (Same as 6)
6 Hidro pol 2 time RW Val: 300 012C	0...999	Minutes	300	Polarity 2 of hydrolysis cell. (Same as 5)
7 Hidro dead time RW Val: 1 0001	0...5	Minutes	1	Dead time hydrolysis cell. (Min. 1 min)
10 pH setpoint mode RW Val: 1 0001	0...2		1	0 - Acid and base are activated – controls 2 relays: relay pH and relay AUX 1. 1 - Only controls Acid: Relay pH. 2 - Only controls Base: Relay pH.
14 Show/use temperature RW Val: 1 0001	0...1		1	0 - Temperature is not shown. 1 - Temperature is shown in display if the temperature probe is connected.
15 Heating RW Val: 1 0001	0...1		1	0 - The Temperature probe does not control the heating relay. The relay AUX4 can be used as "auxiliary relay". 1 - The Temperature probe controls the heating relay. 2 - Maximum and minimum temperature controls the heating connected to Relay AUX 4, allowing the cooling and heating of the pool.

Attention: The faster the polarity change, the shorter is the life time of the cell! The life time guarantee will expire.

E) TYPE OF PUMP



E.2 With the **plus/minus** keys, select the pump type connected to the system (the default is a standard pump type). The configuration allows the control of two different variable speed pumps (Variable Speed A or Variable Speed B). In case of a variable speed pump (A or B), establish the speed when the cover is closed, when the pool heating is connected and/or it controls a backwash filter (Besgo).




E.3 Variable Speed Pump A (Hayward® or similar): During the filtration periods, the corresponding relay closes. The filtration pump opens and closes contacts depending on the speed:
Common + 1 – Slow speed
Common + 1 + 2 – Medium speed
Common + 1 + 2 + 3 – Fast speed
Variable Speed Pump A B (Speck® or similar): During the filtration periods, the corresponding relay closes. It's necessary to connect a wire from the filtration relay to the common. The filtration pump opens and closes contacts depending on the speed:
Common + 1 – Slow speed
Common + 2 – Medium speed
Common + 3 – Fast speed

Consult the wiring-schemata in the appendix!

F) DOSING PUMPS

Atit. reikl. 1.8 ir 1.9




OK

↶



OK

↶



F.2 There are 2 modes for the pH dosing pump:
F.3 Normal: Delay - Delay time between detection of incorrect value and the start of dosing.
F.4 Repetitive: With the two timers you can programm the ON and OFF time of the dosing pump
F.6 Other pumps: With the two timers you can programm the ON and OFF time of the dosing pump
F.8 It corresponds to the behavior of the system after AL3 activation:
 Ignore – AL3 is not shown in the display.
 Inform – After the selected interval, the AL3 alarm is displayed.
 Force stop – After the selected interval, the AL3 alarm is displayed on the display and the dosing pump stops. To reset the alarm and the dosing pump, press ↶.




OK

↶



OK

↶



OK

↶



Atit. reikl. 1.10

F.10 You can associate the level sensor (TANK) to the pH or chlorine (rX). This menu corresponds to the behavior of the system after the TANK signal activation (acid deposit level TANK).
 Ignore – TANK is not shown in the display
 Inform – When the sensor detects that the level is low, the TANK alarm is displayed.
 Force stop – When the sensor detects that the level is low, the TANK alarm is displayed and the associated dosing pump stops.



OK

↶



G) EXTRA SETTINGS



OK

↶



G.2 Gas (0) - The FL1 alarm is only activated by cell's gas sensor (external flow switch annulled).
Siempre ON (1) - The FL1 alarm is never activated (invalidates cell's gas sensor and external flow switch);
Paddle (2) - The FL1 alarm is activated by external flow switch (gas sensor annulled).
Paddle or gas (3) - When both cell's gas sensor and external flow switch are connected, and either of them detects lack of flow, The FL1 alarm is activated. To connect the external flow switch use the FL1 terminal
Paddle + Gas (4) - When both cell's gas sensor and external flow switch are connected, and both of them detects lack of flow, The FL1 alarm is activated. To connect the external flow switch use the FL1 terminal
Paddle delay - Delay before FL1 is activated
Relay control through flow detection - Manage the FL1 alarm deactivation in case of lack of flow. Recommended option for flocculant dosification or similar.



OK

↶



OK

↶



OK

H) COUNTERS


H.2 Reset counters: There are two levels of working hours counters which log the working hours of the components and devices.
 In this service menu the installer can reset the working hour counters on the first level (for example when a new cell is installed).
 The second level of the working hour counters can only be accessed by the factory.

I) CONNECTION



OK

↶




I.2 Node addr: Used for the configuration of more than 2 user interfaces.
 For normal operation of the system, keep the value to 1 for this parameter.

K) WEB IP



OK

↶



K.2 Server control and connection port in case there is WIFI Module connected to the system.
 For the proper functioning of the system, do not change the default values unless you receive a notice from your provider.
 Atitik. reikl. 1.2