



**G. Samaras S.A.**  
MEDICAL GAS SYSTEMS

Thermi industrial area  
57001 Thessaloniki  
Greece  
Tel: +30 2310463388  
Fax: +302310464570  
Email: [sales@gsamaras.gr](mailto:sales@gsamaras.gr)  
Web: [www.gsamaras.gr](http://www.gsamaras.gr)

This directive refers to the vessels of the MO2CSS. Hereby given a draft of the DoC of the vessels used at our system.

In case of an order, there will be a certificate about the exact SN of the station.

**SICCtech** SRL

SICC TECH S.r.l. unipersonale  
Viale Porta Po, 89 Z.I. - 45100 Revigo (RO) ITALY  
Phone +39 0425 403111 r.a. - Fax +39 0425 403177  
Internet <https://www.sicc-tech.it> - Email: [info@sicc-tech.it](mailto:info@sicc-tech.it)

Dichiarazione di conformità UE in applicazione della Direttiva 2014/68/UE EU declaration of conformity according to Directive 2014/68/EU EU konformitätserklärung gemäß der Richtlinie 2014/68/EU Déclaration UE de conformité application de la Directive 2014/68/UE Declaración UE de conformidad conforme a las disposiciones de la Directiva 2014/68/UE	
Collaudo numero <i>Prüfnummer / Inspection no. / Numero d'ispezione/Numero de Prueba</i>	23610
Descrizione componente <i>Beschreibung / Description / Descripción</i>	Serbatoio a pressione <i>Druckbehälter / Pressure vessel / Réservoir sous pression / Recipiente de presión / Recipiente a presión</i>
Capacità (V) <i>Inhalt / Capacity / Capacidad / Capacidad</i>	3000 litri / liter / litres / litros
Fluido contenuto <i>Füllstoff / Fluid / Fluido / Fluido</i>	Fluidi Gr.1 - 2 (escluso idrogeno) Fluidgruppe 1 - 2 (Wasserstoff ausgeschlossen) Fluid Gr.1 - 2 (except hydrogen) Fluido Gr.1 - 2 (excluse de l'hydrogène)
Pressione massima ammessa (PS) <i>Zulässige Betriebsdruck / Max. allowed pressure / Pressioni max. de servicio / Presión máxima de servicio</i>	11.5 bar
Temperatura massima ammessa (T max.) <i>Max. Betriebstemperatur / Max. allowed temperature / Temperatur max. de servicio / Temperatura máxima de servicio</i>	+120 °C
Temperatura minima ammessa (T min.) <i>Min. Betriebstemperatur / Min. allowed temperature / Temperatur min. de servicio / Temperatura mínima de servicio</i>	-10 °C
Tipo <i>Typ / Type / Type / Tipo</i>	3000 - 20011
Numero di fabbrica <i>Fabrik Nr. / Serial No. / N° de fabrico / N° de plano de proyecto</i>	25.02397.001 + 25.02397.020
Disegno di progetto numero <i>Zeichnungsplan Nr. / Design drawing No / Dessin de plan no. / n° de plano de proyecto</i>	20011 Rev.4
Codice utilizzato per la costruzione <i>Fertigungskode / Construction code / Code de construction / Código de construcción</i>	VSR/SIM Rev.1995 Ed.1999 + racc. CTI-R2: 2005 + Directive 2014/68/EU
Categoria / Kategorie / Category / Categoría / Categoría	IV
Modulo utilizzato per l'accertamento di conformità <i>Verwendeter Formblatt für die Konformitätsprüfung / Conformity assessment module used / Formulário utilizado para la verificación de conformidad / Módulo utilizado para la evaluación de la conformidad</i>	B (TIS-PED-MI-18-08-368623-13316 Rev.3) + D (CE-1370-PED-D-SCT 001-24-ITA)
Organismo notificato <i>Benannte Stelle / Notified Body / Organismo notificado / Organismo notificado</i>	Bureau Veritas 1370 Viale Monza 347, 20126, Milano

La presente dichiarazione di conformità è rilasciata sotto la responsabilità esclusiva del fabbricante.  
*This declaration of conformity is issued under the sole responsibility of the manufacturer.*  
*Die alleinige Verantwortung für die Ausstellung dieser Konformitätserklärung trägt der Hersteller.*  
*La présente déclaration de conformité est établie sous la seule responsabilité du fabricant.*  
*La presente declaración de conformidad se expide bajo la exclusiva responsabilidad del fabricante.*

Allegati: istruzioni di uso, installazione e manutenzione, schema dell'apparecchio.  
*Anlagen, Wartungs- und Installationsanweisungen, Plan des Geräts.*  
*Enclosures: instructions for use and maintenance, equipment drawing.*

**G. SAMARAS S.A.**  
MEDICAL GAS SYSTEMS  
PO BOX 1000 57001 THESSALONIKI  
GREECE  
TEL: +302310463388  
VAT N. 0123456789